

430

**FORM 'H'**  
**FORM FOR ISSUING FIRE SAFETY CERTIFICATE**  
[Refer sub - rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No. F6/DFS/MS/SZ/2022/School/461

Dated: 27/04/2022

**FIRE SAFETY CERTIFICATE**

Certified that the building **Fouji Model School**, Located at, **Ground + 02 Upper Floors F-8, Mahavir Enclave –III (Madhu Vihar) New Delhi – 110059** in a building comprised of Ground + 03 Upper Floors, owned/ occupied by **Fouji Model School** have complied with the fire prevention and fire safety requirements in accordance with the Director of Education Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 10/04/2022 in the presence of Sh. Jagat Singh Lochab (Manager) and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B – 1 with effect from ..... for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..... at New Delhi by.

  
(Anil Garg)  
Director  
Delhi Fire Service

**Copy to:-**

1. The Principal, Fouji Model School, Located at Ground + 02 Upper Floors F-8, Mahavir Enclave –III (Madhu Vihar) New Delhi – 110059.
2. Directorate of Education Old Secretariat Delhi – 110054.

**Following fire safety directives must be adhered to:-**

1. **The 3<sup>rd</sup> Floor has been partially damaged & electric supply has been cut down. Floor shall not be used for school activities. (Undertaking Placed at C/ 07 & C/19)**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. Basement shall be used as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

NH

**Re inspection to see the compliance of shortcomings communicated vide letter dated 16/08/2021 are complied**

**INSPECTION REPORT**

1. Name & address of the building: Fouji Model School, **Located at F-8, Mahavir Enclave –III (Madhu Vihar) New Delhi – 110059.**
2. Type of Occupancy : Educational School **Placing at Ground + 2 Upper Floor & building comprised at Ground +three upper floor**
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : 3298 -3398 Dated 01/03/2011.
6. Date of inspection : 10/04/2022
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer  
from the building side :Sh. Jagat Singh Lochab (Manager)
9. Year of Construction : 2006
10. Applicant's letter No. : Email Dated 02-02-2021

Total Area = 850 sqm.
Covered Area = 600 sqm
Class rooms = 12
No. of students = 209

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular no-01/03/2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>Accessible</li> <li>01 mtr</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>06 mtr</li> <li>1 mtr</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>NA</li> </ul>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	<ul style="list-style-type: none"> <li>02 Nos.</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>02 Nos.</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>NA</li> </ul>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	<ul style="list-style-type: none"> <li>1.5 m</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>157cm,93 cm</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>NA</li> </ul>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>
	d. No of continuous staircase to terrace	Required	01 No.	MR
	e. Width Of Corridor	Required	Provided	MR
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>

2/10





14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 37 of the Delhi Fire Service Rules 2010.

**Note;- I ) The building is comprised of Ground + 3 Upper Floors. The 3<sup>rd</sup> Floor has been partially damaged & electric supply has ben cut down. Floor shall not be used for school activities. (Undertaking Placed at C/ 07 & C/19)**

Signature of the Inspecting Officer  
 Name *Uday Vir Singh*  
 Designation *DO(S-1)*



*DO(S-1)*  
 Width of the staircases has been considered as per Director of Education Circular, as school is in the record of DFS before 2010. FSC is recommended by *the*  
*18/4/22*  
*DO(S-1)*  
*19/4/22*  
*DO(S-1)*  
*20/4/22*  
*DO(S-1)*  
 C.F.O.