

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/School/WZ/2022/458

Dated: 26/04/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Girls, Sr. Sec, School, P-Block, Sultanpuri, Delhi-110086. (School ID-1412019)** comprised of **Ground + 03 upper floors** owned/ occupied by **Sarvodaya Kanya Vidhyalaya** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on dated **12.04.2022** in the presence of **Mr. Kamlesh Mishra (Project Manager)** and that the building/ premise is fit for occupancy '**Group B Educational**' with effect from ...26/4/2022... for a period of **three years**, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/4/2022 at New Delhi by

  
 (Atul Garg)  
**DIRECTOR**  
 Ph: 011-23414000

**Copy to:**

1. The Principal, Govt. Girls, Sr. Sec, School, P-Block, Sultanpuri, Delhi-110086. (School ID-1412019).
  2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054
- Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)
[http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms)

**INSPECTION REPORT**

1. Name & address of the building : Govt. Girls, Sr. Sec. School, P-Block, Sultanpuri, Delhi-110086
2. Type of Occupancy : Educational (**Ground + 3 upper floors**) (**School ID-1412019**)
3. Type of Case : New Case
4. Details of Previous NOC : NA
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 12.04.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers  
From the building side : Mr. Kamlesh Mishra (Project Manager)
9. Year of Construction : 2021
10. Applicant's letter No. : Online e-mail dated 29.03.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	6.0m 4.5m NA	Provided 5.8m NA	MR MR NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	d. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 NA	02 NA	MR NA
	e. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.5m NA	1.60m NA	MR NA
	f. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	1.5m	1.8m	MR
	f. Door Size	NA	NA	NA
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	NA Natural ventilation	NA MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	45nos. ABC/CO2 ISI marked	60nos. ABC/CO2 Yes	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	03 30mm 5m	Provided Provided Provided	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA



8.	<b>MOEFA</b>	NA	NA	NA
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	• Basement	NA	NA	NA
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450lpm	2 x 450lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	<b>Standby power supply</b>	NA	NA	NA
18.	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

*[Handwritten Signature]*  
15/4/22

Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)

DO (NW)

*[Handwritten Signature]*  
18/04/2022  
By *[Handwritten Signature]* 18/04/2022

*[Handwritten Signature]*  
20/4/2022

*[Handwritten Signature]*

*[Handwritten Signature]*  
21/4

*[Handwritten Signature]*  
21/04/22

*[Handwritten Signature]*

FT letter is put up for kind perusal and  
Signature please.

*[Handwritten Signature]*  
24/04/22  
Director  
*[Handwritten Signature]*

*[Handwritten Signature]*  
- 15/4/22

