

G-39 FT

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/GH/SZ/2022/203

Dated: 21/04/2022

FIRE SAFETY CERTIFICATE

Certified that M/s. TJS Grand Guest House located at 16/7, W.E.A, Arya Samaj Road, Saraswati Marg, Karol Bagh, New Delhi- 110005, was granted FSC for building comprised of basement, ground plus three upper floors, using ground floor having 05 guest rooms, first floor having 04 guest rooms, second & third floor each having 07 guest rooms respectively (total 23 guest rooms) by this department vide letter No. F.6/DFS/MS/GH/SZ/2019/1014 dated 14.05.2019. The guest house was re-inspected by the officer concerned of this department on 06.04.2022 in the presence of Sh. M.S.Bisht (Manager) and found that the owner/occupier have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential (Guest House) **for basement as incidental storage, ground floor having 05 guest rooms, first floor having 04 guest rooms, second & third floor each having 07 guest rooms respectively (total 23 guest rooms only)** with effect from 21/04/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 21/04/2022 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Following Fire Safety Directives must be adhered to: -

1. No occupancy used above third floor and basement use for only storage purpose and undertaking and photocopy of MCD licence for 08 nos of beds on 2nd & 3rd floor shall be strictly adhered by Owner/Occupier.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate. six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s. TJS Grand Guest House, 16/7, W.E.A. Arya Samaj Road, Saraswati Marg, Karol Bagh, New Delhi- 110005.
2. Type of Occupancy : Lodging House
3. Building Composition : Building comprised of basement, ground plus three Upper Floors using basement as incidental storage, ground floor (5 guest room), first floor having 4 guest rooms, second & third floor each having 07 guest rooms (total 23 guest rooms only)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/GH/2019/SZ/1014 dated 14.05.2019
6. Fire Safety directives letter No : Nil
7. Date of inspection : 06.04.2022
8. Name of the Inspecting Officers : P.V. Rathee, Asst. Divisional Officer (SRD)
9. Name and designation of officers from the building side : Sh. M.S.Bisht (Manager)
9. Year of Construction : Before 2009
10. Applicant's letter No. : Online Application no. 2022033004538 dated 31.03.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety requirements as per FSC dt. 14.05.2019	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	06 mts.	MR
	• Gate width	N/A	Directly accessible from the road	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	01	01	MR being old case
	• Basements	02	02	MR being old case
	b. Width of staircases	-	-	-
	• Upper Floors	1.25 mts.	1.25 mts	MR being old case
	• Basements	1.25 mts.	1.25mts & 1.22 mts.	MR being old case
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.0 mts.	1.10-1.40mts	MR (old case)
	h. Door Size	1.0 mts.	0.87 mts	MR being old case
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	sealed	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5	Fire Extinguishers			
	• Total numbers	15	Provided	MR
	• Types	CO ₂ , ABC, WCO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Carbon Monoxide	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	D.G. set 65 KVA	MR
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	---	---	---
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	-----	-----	-----
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 mts each	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	6000 lts	6000 Lts.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			

N/19

MR	• Pressurization of Lift Shaft	N/A	N/A	N/A
MR	• Pressurization of Lift lobby	N/A	N/A	N/A
MR	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Required	Provided	MR
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked at random and found satisfactory at the time of inspection.

Note:- Undertaking and photocopy of MCD license for 08 No. of beds on 2nd & 3rd floor given by owner/occupier (placed at C-36 & C-37)

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No. F6/DFS/MS/GH/2019/SZ/1014 dated 14.05.2019, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. DFA is put up for approval & signature please.

[Handwritten Signature] 8/4/22

Signature of the Inspecting Officer
P.V. Rathee
Asstt. Div. Officer (SRD)

D.O. (SW)
[Handwritten Signature]

F.I/c

8/4/22
Dy. Insp. (S2)
[Handwritten Signature]
A. Das (SRD)