

C-24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F6/DFS/MS/School/2022/NDZ/ 476

Dated: 29/04/2022

FIRE SAFETY CERTIFICATE

Certified that M/s Fahan International School running on ground plus one floor only of the building comprised of small basement plus ground plus one upper floor at Between Block B-2 & B-3, Yamuna Vihar (Behind Mohan Nursing Home), Delhi-110053, owned/occupied by Fahan International School was issued FSC for ground plus first floor vide letter No. F.6/DFS/MS/School/2019/NDZ/951 dated 07/05/2019. The school building was re-inspected by the officer concerned of this department on 20/04/2022 in the presence of Mr. S.H.M Naqui, Manager of the school and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with circular letter no. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education and observed that ground plus first floor of the building is fit for occupancy class 'Educational Building' "Group-B" with effect from 29/04/2022 for a period of **three** years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.subject to conditions, printed overleaf.

Issued on 29/04/2022 at New Delhi by


28/4/22

**(Dr. S.K Tomar)
Dy. Chief Fire Officer**

To,
The Manager,
M/s Fahan International School,
Between Block B-2 & B-3, Yamuna Vihar,
(Behind Mohan Nursing Home),
Delhi-110053

Copy:-

- 1) The Commissioner,(EDMC)
Udyog Sadan, Plot No.419, FIE,
Patparganj Industrial Area,
Delhi-110092

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The basement shall not be used for school purpose.

- 2114
1. Name & address of the building : Fahan International School,
Between Block B-2 & B-3, Yamuna Vihar,
(Behind Mohan Nursing Home) Delhi-110053
 2. Building is comprised of : Small basement plus ground plus one upper floor
(School is running on ground & first floor)
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC letter : F.6/DFS/MS/School/2019/NDZ/951 dated 7/05/19
 6. Fire Safety direction letter No : F16/Estate/CC/FireSafety/2011/3298to3398 dt-01/03/11
 7. Date of Inspection : 20/04/2022
 8. Name of the Inspecting officers : ADO Mehmood
 9. Name and designation of Officer
from the building side : Mr. S.H.M Naqui, Manager
 10. Year of Construction : 2005 & 2007
 11. Applicant's letter No : 0-22/05 dated 11/04/2022

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	• Road width	06 mtr.	06 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 nos.	02 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 mtr.	1.50 mtr & 0.54 mtr	MR
	• Basement	1.50 mtr	01 mtr (old accepted)	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 nos.	01 nos.	MR
	e. Width of Corridor	1.50 mtr.	1.67 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A

2115

05.	Fire Extinguishers			
	• Total numbers	06 nos.	07 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor	N/A	Provided	MR
	• Length of hose reel hose	N/A	Provided	MR
	• Nozzle diameter	N/A	Provided	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	225 lpm	MR
	➤ Head of the Pump	N/A	40 mtr	MR
	➤ Power supply	N/A	Provided	MR
	➤ Auto Starting of pump	N/A	N/A	N/A

N/16

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2500 ltr	2500 ltr	MR
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/SCHOOL/2019/NDZ/951 Dated 07/05/19 renewal under rule 35 of Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name :- Mehmood
 Designation :- A.D.O (T.P)



DO(ED)

25/04/2022
 Dy. CPO (NDZ)

25/4/22

A.D.O (T.P) [Signature]

28/4/22

28/4/22

28/4/22
 A.D.O (T.P)