

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/ 188

Dated: 29.04/2022

FIRE SAFETY CERTIFICATE

Certified that Block- A, B + C + D + E + F Additional Office Complex at Supreme Court of India, Near Pragati Maidan, New Delhi comprised of Block- B + D + E - 3 Basement + Ground + 08 upper floors, Block- A& C, 3 Basement + Ground + 05 upper floors Auditorium (without seats), Block – F, 3 Basement + Ground + 03 upper floors owned /occupied by Supreme Court of India was earlier granted FSC vide letter No. F6/DFS/MS/ NDZ/2019/500 dated 11/03/19 (block -A) & No. 755 dated 08/04/19 (other blocks). Now, The premises was re-inspected by the officer concerned of this department on 13/04/2022 in the presence of Sh. Gyanandu, AE (E) & Sh. Pitesh, EE(E) and found that the said building block has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Business Building** with effect fromfor period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued onat New Delhi by.

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Executive Engineer (E),
Office of the Chief Project Manager,
Supreme Court Project, CPWD, Gate No. 9, Pragati Maidan, New Delhi – 110001.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration shall strictly prohibited. And if used same shall be of 02 hr fire rating.

N/15
INSPECTION REPORT

- 1 Name & address of the building: **A,B, C,D, E & F Block** Additional Office Complex for Supreme Court of India, Near Pragati Maidan, New Delhi.
2. Type of occupancy:- **Business Building**
Block A , 03 Basement + Ground + 05 upper floor
Block- B, D, E - 3 Basement + Ground + 08 upper floors,
Block- C, 03 Basement + Ground + 05 upper floors,
Block -F - 3 Basement + Ground + 03 upper floors,
3. Type of case:- **Renewal**
4. Details of previous FSC:- **F6/DFS/MS/NDZ/2019/500 dated 11/03/19(A block)) & for B,C,D,& F block**
F6/DFS/MS/NDZ/2019/755 dated 08/04/19
F6/DFS/MS/BP/2012/1771 dated 15/05/12
5. Fire safety directives No.- **13/04/2022**
6. Date of inspection:- **13/04/2022**
7. Name of the inspecting officer:- **Sh. Rajinder Atwal DO/CD**
Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- **Sh. Gyanandu AE E) & Sh. Pitesh, EE(E)**
9. Year of construction:- **2014-15**
10. Applicant's letter No:- **54(FF) E. Eng. (E)/CPWD/2022-23/423 dated 07.04.2022**

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC-IV	Provided at site	Remarks MR/NMR
1	Access to Building			
	1) Road width	09 mtr.	12 mtr.	MR
	2) Gate width	05 mtr.	05 mtr.	MR
	3) Width of internal road	06 mtr.	06 mtr.	MR
2	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	Block A - 05 Nos. Block B - 06 Nos. Block C - 03 Nos. Block D - 04Nos. Block E - 01 Nos. Block F - 02Nos.	Block A - 05 Nos. Block B - 06 Nos. Block C - 03 Nos. Block D - 04Nos. Block E - 01 Nos. Block F - 02Nos.	MR
	2. Basements	Block A - 05 Nos. Block B - 06 Nos. Block C - 03 Nos. Block D - 04Nos. Block E - 01 Nos. Block F - 02Nos.	Block A - 05 Nos. Block B - 06 Nos. Block C - 03 Nos. Block D - 04Nos. Block E - 01 Nos. Block F - 02Nos.	MR
	B. Width of staircase			
	1. Upper floors	1.5 mtr.& 2.0 mtr	1.5 mtr.& 2.0 mtr	MR
	2. Basements	1.5 mtr.	1.5 mtr. each	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace	Block A - 05 Nos. Block B - 06 Nos. Block C - 03 Nos. Block D - 04Nos. Block E - 01 Nos. Block F - 02Nos.	Block A - 05 Nos. Block B - 06 Nos. Block C - 03 Nos. Block D - 04Nos. Block E - 01 Nos. Block F - 02Nos.	MR
	E. Width of corridor	2.0 m	2.0 m	MR
	F. Door size	1.5 m & 2.0 m	1.5 m & 2.0 m	MR
3	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR

	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12ACPH	Provided	MR
5	Fire Extinguishers			
	1) Total numbers	150 Nos.	Provided	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6	First-Aid Hose Reel			
	1) Total number of each floor	05	05	MR
	2) Length of hose reel hose	30 mm	30 mm	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Required	Provided	MR
	3) Location of repeater panel	Required	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	1) Size of riser/down-comer	150 mm	150 mm	MR
	2) Number of hydrants per floor	05	05	MR
	3) Hose box	05	05	MR
12	Yard Hydrants			
	1) Total number of hydrants	05	05	MR
	2) Hose box	05	05	MR
13	Pumping Arrangement	Common Block – A, B, C, D, E & F		
	1) Ground level			
	a) Discharge of main pump	2280 LPM	2850 LPM	MR
	b) Head of main pump	70 mtr.	70 mtr.	MR
	c) Number of main pump	02	02	MR
	d) Jockey pump out put	180 LPM	220 LPM	MR
	e) Jockey pump head	70 mtr.	70 mtr.	MR
	f) Stand by pump output	2280 LPM	2850 LPM	MR
	g) Stand by pump head	70mtr.	70mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	Common Block – A, B, C, D, E & F			

4/8

	1) Underground tank capacity	1,50,000 ltr.	1,50,000 ltr.	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20000 ltr.	20000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts			
	a) Pressurization of lift shaft	Required	Provided	MR
	b) Pressurization of lift lobby	Required	Provided	MR
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20	Special Fire Protection System for Protection of special Risk, if any: Total flooding system provided.			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, FSC issued vide letter no. F6/DFS/ MS/ NDZ/2019/500 dated 11/03/19 & No. 755 dated 08/04/19, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name: - Sh. Rajinder Atwal
Designation: - DO/CD

Name: - Ravinder Singh
Designation: - ADO (CC)



Dy. C.F.O. (AD 2)

Rajinder
25/4/22

CFO/CD

Rajinder
25/4/22

On 27/04/22

AD 10
27/4

Adm (CC)

421
27/04