

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/CNG/WZ/2022/ 187

Dated: 27/04/2022

**FIRE SAFETY CERTIFICATE**

Certified that the CNG Station at Khasra No.142, Khata No.582/2, Plot No.276/2, Village & Tehsil Kanjhawala, Delhi-81, comprised of Single Story Building. The building was inspected by the officer concerned of this department on 04.04.2022 in the presence of Sh. Narender Kumar Dabas (Owner) and found that the building have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the building is fit for occupancy Hazardous (Group-J) with effect from ...27/04/2022...for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/04/2022 at New Delhi by



(Atul Garg)  
**DIRECTOR**

Ph; 011-23414000

**Copy to:**

1. Sh. Narender Kumar Dabas (Owner) DODO CNG Station, Kanjhawala, Delhi-110081.
2. The Addl. Commissioner of Police (Lic), 1<sup>st</sup> Floor, Police Station, Defense Colony, Delhi

**Conditions for the validity of fire safety certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

**INSPECTION REPORT**

1. Name & address of the building : CNG Station at Khasra No.142, Khata No.582/2, Plot No.276/2, Village & Tehsil Kanjhawala, Delhi-81.
2. Type of Occupancy : Group J Hazardous Building (Single Story Building)
3. Type of Case : New Case
4. Details of Previous NOC : NA
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2022/CNG/04 dated 05.01.2022.
6. Date of inspection : 04.04.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers  
From the building side : Sh. Narender Kumar Dabas (Owner)
9. Year of Construction :
10. Applicant's letter No. : Online e-mail dated 14.02.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	25m	30m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	<b>Fire Extinguishers</b>			

N14

Captive

	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	75kg-14 10kg-25 4.5kg-04CO2	Provided	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC/CO2/DCP	Provided	MR
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	ISI marked	Yes	MR
<b>6.</b>	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	NA	NA	NA
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	IR Cap/NA Compressor	NA Provided	NA
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	NA	NA	NA
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	NA	NA	NA
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Ground &amp; Upper Floors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
<b>12.</b>	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
<b>13.</b>	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual Stopping</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	NA	NA	NA


NIS

	➤ Auto Starting of pump	NA	NA	NA
	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
	<b>Exit Signage.</b>	NA	NA	NA
	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	<b>Standby power supply</b>	NA	NA	NA
18.	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	Fire buckets filled with sand, no smoking boards and emergency exits were found displayed in Hindi. No loose electric wiring seen provided flood lighting system found provided	and, no fire buckets filled with sand, no smoking boards and emergency exits were found displayed in Hindi. No loose electric wiring seen provided flood lighting system found provided	NR

The fire protection systems provided in the building were tested and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards for fire prevention and fire safety required under the rules it is recommended to grant Fire Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of Deputy Commissioner  
 Date: 15/4/22  
 Name: Sharmila  
 Designation: Deputy Commissioner



DO (NW)

Handwritten signatures and dates:  
 06/06/2022  
 18/4/2022  
 20/04/22  
 20/04/22

ADJ Rom