

31/05/2022

C/SO

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI**

Dated: 02/05/2022

No. F6/DFS/MS/EH/WZ/2022/ 112

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Duty free ( A Unit of Night House Cafe Pvt. Ltd.) running at Upper Ground floor located at C-10, Upper ground floor, Vishal Enclave, Rajouri Garden, New Delhi-110027 of a building comprised of Basement +Stilt + Upper Ground + Two Upper Floors. Owned/Occupied by M/s Duty free (A Unit of Night House Cafe Pvt. Ltd.) was inspected by the officers concerned of this department on 19/04/2022 in the presence of Sh. Varun puri and found that the owner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and that the premises is fit for occupancy class "Assembly" Group D (Upper Ground floor only) with effect from 02/05/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 02/5/2022 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The owner/occupier, M/s Duty free ( A Unit of Night House Cafe Pvt. Ltd.) at C-10, Upper ground floor, Vishal Enclave, Rajouri Garden, New Delhi-110027 (Reference: - ID No. 2022033104752 dated: - 31/03/2022)
2. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi.
3. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per Building Bye Laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. **The NOC is valid for Upper ground floor only.**
10. No electric cable, panel shall be passed through staircases & garbage's/LPG cylinder shall be stored into the staircases.

**INSPECTION REPORT**

1. Name & address of the building : Dutyfree (A unit of Night House Café Pvt. Ltd), C-10,  
Upper Ground Floor, vishal Enclave, Rajouri garden, New  
Delhi-110027.
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Nil
6. Date of inspection : 19/04/2022
7. Name of the Inspecting Officers : DO(West) & ADO (MN)
8. Name and designation of officers  
from the building side : Sh. Varun Puri (Owner)
9. Year of Construction :2000 (As per MHA Portal)
10. Applicant's letter No. : Online application No.2022033104752 dated 31/03/2022
- \* **The said restaurant is running at upper ground floor in a building comprised of Basement + Stilt + Upper ground + 1<sup>st</sup> + 2<sup>nd</sup> Floor.**

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09 mts	On main road	MR
	• Gate width	4.5mts	On main road	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	2	2	MR
	• Basements	N/A	N/A	MR
	b. Width of staircases			
	• Upper Floors	2 X 1.5m	2 X 1.5m Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	2 X 1.5 m	2 X 1.5m Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	NA	N/A	N/A
	• Upper floors	Required	Provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	5	6	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

V-2

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/ Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NR	NR	NR
	➤ Draw-off connection	NR	NR	NR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

15

N-8

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection. The Shortcomings issued by this department vide Letter no. F6/DFS/MS/EH/2022/184 Dated- 11/02/2022 have been compiled.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

103/ADO/MN  
22/04/2022


D.O. (WEST) 461  
DATED: 24/4/2022

*[Signature]*  
22/4/2022

*[Signature]*  
22/4/2022

Signature of the Inspecting Officer  
Name: - M. K. Chattopadhyay  
Designation: - DO (West)

Signature of the Inspecting Officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)



*[Signature]*  
DO (WZ)  
29/4/22

*[Signature]*  
28/4/2022

*[Signature]*  
29/4/22

*[Signature]*