

C-32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/EH/2022/SZ/107

Dated: 27/4/2022

FIRE SAFETY CERTIFICATE

Certified that the **M/s Haldiram Products Pvt. Ltd.** Running at ground floor only in a building comprised of two Basements, Ground plus eight upper floors & terrace floor located at Unit No.-GF-10 & 11, Unity One, Near Janak Puri West Metro Station, Janakpuri, New Delhi-110058, owned/occupied by M/s Haldiram Products Pvt. Ltd. was issued FSC by this department vide letter no. F6/DFS/MS/EH/2019/SZ/1263 dated 13/06/2019. The restaurant building was re-inspected by the officers concerned of this department on 06/04/2022 in the presence of Sh. Shiv Kumar (Manager) and found that restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant at Ground Floor Only is fit for occupancy class Group-D "Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on.....27/4/2022..... at New Delhi.


Director

Delhi Fire Service

Copy to:-

1. The Manager,
M/s Haldiram Products Pvt. Ltd., Unit No.-GF-10 & 11,
Unity One, Near Janak Puri West Metro Station, Janakpuri,
New Delhi-110058.
2. The Dy. Health Officer,
S.D.M.C, Public Health Department, West Zone,
Vishal Enclave, Rajouri Garden, New Delhi-110027

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Haldiram Products Pvt. Ltd., Unit No.-GF-10 & 11, Unity One, Near Janak Puri West Metro Station, Janakpuri, New Delhi-110058.
2. Building comprised of : 2 basements, ground plus eight floors & terrace but restaurant running at ground floor only
3. Type of Occupancy : Group D (Assembly)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/EH/2019/SZ/1263 dated 13/06/2019
6. Fire Safety directives letter No : F6/MS/DFS/MS/BP/2014/207 dated 28.07.2014 (for whole bldg.)
7. Date of inspection : 06/04/2022
8. Name of Inspecting Officers : A.D.O. R.K.Yadav
9. Name and designation of officers From the building side : Sh. Shiv Kumar (Manager)
10. Year of Construction : 2015
11. Applicant's letter No. : Application ID No. 2022032504208 dated 25/03/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mtrs. 06 mtrs. 06 mtrs.	Provided Provided Provided	M/R M/R M/R
2.	Number, Width, Type & Arrangement of Exits	(Restaurant at GF only)		
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	03 No's 03 No's	03 No's 03 No's	M/R M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 m each 1.50 m each	1.50 m (03 no's) 1.50 m (03 no's)	M/R M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required Required	Provided Provided	M/R M/R
	d. No. of continuous staircases to terrace			
		Required 1.50 m	Provided Opening in hall	M/R M/R
	e. Width of Corridor	02 m	2.1, 2.16 & .9 m	M/R
	f. Door Size			
3.	Compartmentation	(Restaurant at GF only)		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required Required 02 hrs Required Required	Provided Sealed Provided Provided Provided	M/R M/R M/R M/R M/R
4.	Smoke Management System	(Restaurant at GF only)		
	<ul style="list-style-type: none"> • Basements • Upper floors 	Required Required	Provided Provided	M/R M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers in restaurant • Types • IS marking 	05 no.'s ABC/CO ₂ ISI marked	Provided Provided Provided	M/R M/R M/R

(Handwritten mark)

6.	First-Aid Hose Reels	(Common with parking cum commercial building)		
	<ul style="list-style-type: none"> Total numbers for restaurant Length of hose reel hose Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	M/R M/R M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Smoke/Heat Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required Required N/A Required Required	Provided Provided at GF N/A Provided Near exit	M/R M/R N/A M/R M/R
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System	(Restaurant at GF only)		
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required Required Required	Provided Provided Provided	M/R M/R M/R
11.	Internal Hydrants	(Common with parking cum commercial building)		
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants for restaurant Hose Box 	150/100 mm One One	Provided Provided Provided	M/R M/R M/R
12.	Yard Hydrants For entire building	(Common with parking cum commercial building)		
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Seven Seven	Provided Provided	M/R M/R
13.	Pumping Arrangements For entire building	(Common with parking cum commercial building)		
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Water curtain Pump Auto Starting/Manual Stopping 	2850 LPM 90 mtrs Two 280 LPM 90 mtrs 2850 LPM 90 mtrs 1000 LPM Required Required	2850 LPM 90 mtrs Two 280 LPM 90 mtrs 2850 LPM 90 mtrs 1000 LPM Provided Provided	M/R M/R M/R M/R M/R M/R M/R M/R M/R M/R
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 LPM 40 mtrs Required Required	900 LPM provided Provided Provided Provided	M/R M/R M/R M/R
14.	Captive Water Storage for fire fighting	(Common with parking cum commercial building)		
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	2,00,000 ltrs Required Required Required 10000 ltrs	2,00,000 ltrs Provided Provided Provided 20000 ltrs. provided	M/R M/R M/R M/R M/R
15.	Exit Signage.	Required	Provided	M/R

pc

N/A

		(Restaurant at GF only)		
16.	Provision of Lifts. <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
17.	Standby power supply			
18.	Refuge Area. <ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	Provided	M/R

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the fire safety certificate issued vide letter no. F6/DFS/MS/EH/2019/SZ/1263 dated 13/06/2019 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- The restaurant is at ground floor level in the Multi Level Car Parking cum Commercial area, Janak Puri West Metro Station, New Delhi and have common fire safety installations. The FSC was issued to Multi Level Car Parking cum Commercial area vide letter no. F.6/DFS/MS/PRKG/2022/SZ/56 dated 08/02/2022.

R. K. Yadav

Signature of Inspecting Officer
 Name:- R.K.YADAV
 Designation:- Asstt. Divisional Officer

D.O. (South West) *[Signature]*

13/4/22

Dy. CEO (SZ)

G.F.O. (D. aff)
 Director *[Signature]*
 20/04/2022

FFPS
 Dd/SW *[Signature]*
 21/4/22
 ADO JNK Puri