

view document

46

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2022/ 109

Dated: 28/04/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Nazeer Food (Nazeer Hospitality foods limited)** located at **G 09, G.F, Ground Floor, V3S Mall, Plot No. 10, Laxmi Nagar, Delhi** building comprised of **Basement + Ground + 03 Upper floors, Restaurant running on ground floor only** owned/occupied by Nazeer Food (Nazeer Hospitality foods limited). The premises was inspected by the officer concerned of this department on **20/04/2022** in the presence of **Mr. Atul Singh (G.M)** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Assembly Building Group D, Restaurant running on ground floor only** with effect from 28/4/2022 for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 28/4/2022 at New Delhi by.

  
(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

- 1 The Deputy Commissioner (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi.  
**Online application ID no. 2022030403040.**
- 2 The Manager,  
Nazeer Food (Nazeer Hospitality foods limited),  
G 09, G.F, Ground Floor, V3S Mall, Plot No. 10, Laxmi Nagar, Delhi.

Condition for the validity of fire safety certificate

- 1 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- 7 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
- 9 Any flammable material for interior decoration is prohibited.

**INSPECTION REPORT**

1. Name & address of the building Nazeer Food (Nazeer Hospitality foods limited)  
G 09, G.F, Ground Floor, V3S Mall, Plot No.  
10, Laxmi Nagar, Delhi
2. Type of occupancy:-  
Assembly Building  
B + Gr. + 3 upper floors  
Restaurant running at ground floor only
3. Type of case:-  
New Case
4. Details of previous FSC:-  
N/A
5. Fire safety directives No.-  
N/A
6. Date of inspection:-  
07/04/2022
7. Name of the inspecting officer:-  
Sh. A.K Jaiswal (DO/ED) &  
Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer  
From the building side:-  
Mr. Atul Singh (G.M)
9. Year of construction:-  
2006
10. Applicant's letter No:-  
**2022030403040** dated 13.04.2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	12 mtr.	36 & 13.8 mtr.	MR
	2) Gate width	4.5 m	06 m	MR
	3) Width of internal road	06 m	06 m	MR
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5 mtr.	02 nos. 1.5 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	20 Nos.	39 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR

*(Signature)*

6.	<b>First-Aid Hose Reel</b>			
	1) Total number 1 <sup>st</sup> floor	02	02	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	Smoke/Heat	Provided	MR
	2) Location of main panel	Control Room	Basement	MR
	3) Location of repeater panel	Security room	Provided	MR
	4) Alternate source of power	Battery & DG set	Provided	MR
	5) Hooter's Location	Staircase	Provided	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	150 mm	150 mm	MR
	2) Number of hydrants per floor	02	02	MR
	3) Hose box	02	02	MR
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	05	05	MR
	2) Hose box	05	05	MR
13.	<b>Pumping Arrangement</b>		<b>Common with V3S Mall</b>	
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	70 mtr.	70 mtr.	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	70 mtr.	70 mtr.	MR
	f) Stand by pump output	2850 LPM	2850 LPM	MR
	g) Stand by pump head	70 mtr.	70 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
	14.	<b>Captive Water Storage for Fire Fighting Common with V3S Mall</b>		
1) Under ground tank capacity		1,00,000 ltr.	1,20,000 ltr.	MR
a) Draw-off connection		Required	Provided	MR
b) Fire service inlet		Required	Provided	MR
c) Access to tank		Required	Provided	MR
d) Over head tank capacity		20,000 ltr.	40,000 ltr.	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR

*[Handwritten signature and initials]*

16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any: Provided in all LT &amp; HT Panels.</b>			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer


Signature of the Inspecting Officer

*[Signature]*  
21/04/2022  
Name :- A.K Jaiswal  
Designation :- DO (ED)

*[Signature]*  
21/4  
Name :- M.K. Sharma  
Designation :- ADO (LN)



DY CPO (AD 2)  
*[Signature]*  
22/4/22



CFO/DO  
*[Signature]*

*[Signature]*  
26/04/22

*[Signature]*  
M.K. Sharma

*[Signature]*