

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/Cinema/2022/NDZ/ 200

Dated: 09/05/2022

FIRE SAFETY CERTIFICATE

Certified that M/s Gagan Cinema located at Nand Nagri Delhi-110093 comprised of Basement(Sealed) ,Ground plus Two upper Floors, was issued NOC in the M/s Gagan Cinema by this department vide letter no. F6/DFS/MS/CINEMA/2013/NDZ/490 Dated. 27/06/13. The premises was re-inspected by the officer concerned of this department on 18/04/2022 in the presence of Mr. Rakesh Kumar (Manager) of the cinema hall and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises if is fit for occupancy class 'Assembly Building'(Cinema) with effect from 05/05/2022 for a period of **three** years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions under rule 38 of Delhi Fire Service Rules,2010. subject to conditions, printed overleaf.

Issued on.....05/05/2022.....at New Delhi by

(Atul Garg)
Director

To,
The Manager,
Gagan Cinema
Nand Nagri, Delhi-110093

Copy:-
To
The District Magistrate,
Nand Nagri District,
East Delhi-110093

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
5. Basement is sealed (Brick wall) by the MCD.(Undertaking given by owner)
6. This Fire Safety Certificate may not in any way be treated as regularization (clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016),if any.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

n/84

1. Name & address of the building : Gagan Cinema
Nand Nagri, Delhi-93,
2. Building is comprised of : Ground plus Two upper floors
3. Type of Occupancy : Assembly Building Cinema Single Screen
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/Cinema/2013/NDZ/490 dated- 27/06/13
6. Fire Safety directive letter No : The Delhi Cinematograph Rules 1983
7. Date of Inspection : 18/04/2022
8. Name of the Inspecting officers : DO A.K Jaiswal & ADO Mehmood
9. Name and designation of Officer
from the building side : Mr. Rakesh, Manager
10. Year of Construction : 2006
11. Applicant's letter No : Email, Dated- 25/03/2022

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Cinematograph Act, 1983. Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 mtrs. Required N/A	30 mtrs Provided N/A	MR MR N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	02 nos. N/A	02 nos. N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	1.50 mtrs Sealed	2.80 mtrs each Sealed	MR Sealed
	c. Protection of Exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of Continuous Staircases to Terrace	02 nos.	02 nos.	MR
	e. Width of Corridor	1.50 mtrs	1.70 mtrs	MR
	f. Door Size	1.50 mtrs.	2.80m , 2.50m & 2.80m	MR
	<ul style="list-style-type: none"> • Balcony • Dress Circle • Front Circle 	1.50 mtrs 1.50 Mtrs 1.50 mtrs	1.50 mtrs x 3 nos. 1.50 mtrs x 5 nos. 1.50 mtrs x 3 nos.	MR MR MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	12 ACPH 30 ACPH	Sealed Exhaust Fan	N/A MR
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	48 nos. ABC /CO ₂ ISI marked	48 nos. ABC /CO ₂ ISI marked	MR MR MR

2/186

06	First-Aid-Hose Reels.			
	Total numbers on each floor	02 nos.	02 nos. each floor	MR
	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	30 mtrs.	30 mtrs	MR
		05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power Hooter's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement upper floor sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose box 	Required	01 no.	MR
		Required	01 no.	MR
13	Pumping Arrangements.			
	➤ Ground Level			
	<ul style="list-style-type: none"> Discharge of main pump Head of Main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	➤ Terrace Level			
	<ul style="list-style-type: none"> Discharge of pump Head of the pump Power supply Auto starting of pump 	450 LPM	450 LPM	MR
		40 m	40 m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead tank capacity 	25,000 ltrs	50,000 ltrs	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 ltrs	33,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift Shaft Pressurization of lift lobby Communication in lift car Firemen's grounding switch Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

or/sg

		Required	Provided	MR
17	Standby Power Supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules, it is recommended to renew Fire Safety Certificate under rule 35 of Delhi fire Service Rules 2010..

[Signature]

Signature of the Inspecting Officer
 Name :- A.K Jaiswal
 Designation :- D.O (ED)

[Signature]
 19/4/22

Signature of the Inspecting Officer
 Name :- Mehmood
 Designation :- A.D.O (T.P)

Dy.CFO(NDZ)

No request has been received from lic. Authority
 is. DM/SDM. We may ask for the same!

[Signature]
 21/4/22

CFO(CHE)

[Signature]
 25/4

[Signature]

DY ED *[Signature]*
 29/04/22

ADO/T.P.

[Signature]
 28/4/22

