

117 | ADMIN

E 52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI


No: F6/DFS/MS/School/WZ/2022/ 501

Dated: 09/05/2022

FIRE SAFETY CERTIFICATE

Certified that the **S.N. Public School** located at **R-Z 54, Ravi Nagar, Extn. Khayla New Delhi-110018** comprised Ground plus One Upper floors, Owned/Occupier by **S.N. Public School**, was issued FSC vide letter No. F6/DFS/MS/School/2019/93 dated 11/01/2019. The premises was re-inspected by the officer concerned by this department on 25/04/2022 in the presence of Smt. Neelam yadav (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention & fire safety requirements in accordance with Circular No. 262-362 dated 17/01/2005 issued by the Directorate of education and found that the premises is fit for occupancy class "Educational" Group B with effect from 09/05/2022 for a period of three years subject to the compliance of the conditions mentioned below:-

Issued on 09/05/2022 at New Delhi.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer,
Delhi Fire Service

Copy to:

1. The Principal/Incharge, the Principal, S. N. Public School, R-Z 54, Ravi Nagar, Extn., Khayla, New Delhi-110018
2. Director of Education, Old Sectt. Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N-20

INSPECTION REPORT

1. Name & address of the building : S. N. Public School located at RZ-54, Ravi Nagar, Extn. Khayla New Delhi-110018.
2. Type of Occupancy : Educational (Ground Floor + One Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2019/93 dated 11/01/2019
5. Fire Safety directives letter No : 262-362 dated 17/01/2005
6. Date of inspection : 25/04/2022
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side : Sh. Neelam Yadav (Principal)
9. Year of Construction : 1994 (As per prev. insp. report dtd-24/12/2018)
10. Applicant's letter No. : Letter No. Nil dated -08/04/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement/(As per prev. insp. report dtd-24/12/2018)	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	1 X 90cm, 1 X 85cm,	MR being old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	01 mtr	86 cm Provided	MR being old case
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	05 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

26

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA NA NA NA NA NA NA NA NA 220 lpm 40 m Required Required	NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA MR MR MR MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 2500 Ltrs	NA NA NA NA Found removed	NA NA NA NA NMR
15	Exit Signage.	Required	Found removed	NMR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply			
		NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:			
		NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection. The Shortcomings issued by this department vide Letter no. F6/DFS/MS/School/WZ/2022/98 Dated- 09/03/2022 have been compiled.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/ /2019/93 dated- 11/01/2019 renewal under the circular no. 262-362 dated 17/01/2005 is recommended.

117/ADO/MN
26/04/2022

[Signature]

[Signature]
26/4/22

Signature of the Inspecting Office
Name: Sarabjeet Singh
Designation: ADO (MN)

475/DO/WZ
26/4/2022

[Signature] 26/4/2022

Defo (WZ)

[Signature] 26/4/2022

[Signature] Sir, F.T is put up for your personal & signature please!

[Signature]

[Signature] 05/05/2022

[Signature]