

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/School/WZ/2022/488

Dated: 05/05/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Sarvodaya Kanya Vidhyalaya, H- Block, Sultanpuri, Delhi-110086** (School ID-1412029) comprised of **Ground + 03 upper floors** owned/ occupied by **Sarvodaya Kanya Vidhyalaya** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on dated **25.04.2022** in the presence of **Er. Shashank Sahu (AE)**, and that the building/ premise is fit for occupancy '**Group B Educational**' with effect from 05/05/2022 for a period of **three years**, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/05/2022 at New Delhi by

  
(Atul Garg)  
**DIRECTOR**

**Ph; 011-23414000**

**Copy to:**

1. The Principal, Sarvodaya Kanya Vidhyalaya, H- Block, Sultanpuri, Delhi-110086. (School ID-1412029).
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

N/14

**INSPECTION REPORT**

1. Name & address of the building : Sarvodaya Kanya Vidhyalaya, H- Block, Sultanpuri, Delhi-110086
2. Type of Occupancy : Educational (School Id-1412029)
3. Type of Case : New Case (Ground + 03 upper floors)
4. Details of Previous NOC : NA
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 25.04.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers  
From the building side : Er. Shashank Sahu (AE)
9. Year of Construction : 2021
10. Applicant's letter No. : Online e-mail dated 25.04.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	6.0m	12m	MR
	• Gate width	4.5m	6.0m	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02 + 01 ramp	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	1.5m & 1.6m ramp	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	1.5m	1.7m	MR
	f. Door Size	NA	NA	NA
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	45nos.	84nos.	MR
	• Types	ABC/CO2	ABC-42/CO2-42	MR
	• IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	04	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA



	<ul style="list-style-type: none"> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	NA	NA	NA
8.	<b>MOEFA</b>	NA	NA	NA
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Ground &amp; Upper Floors</li> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11.	<b>Internal Hydrants</b>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	NA	NA	NA
12.	<b>Yard Hydrants</b>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>➢ Discharge of main Pump</li> <li>➢ Head of Main pump</li> <li>➢ Number of main pumps</li> <li>➢ Jockey Pump out put</li> <li>➢ Jockey pump head</li> <li>➢ Standby Pump out put</li> <li>➢ Standby Pump Head</li> <li>➢ Auto Starting/Manual Stopping</li> <li>➢ Pump House Access</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Terrace level</li> <li>➢ Discharge of pump</li> <li>➢ Head of the pump</li> <li>➢ Power Supply</li> <li>➢ Auto Starting of pump</li> </ul>	450lpm	2x 450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➢ Draw-off connection</li> <li>➢ Fire service inlet</li> <li>➢ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000ltr	10,000ltr	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	<b>Standby power supply</b>	NA	NA	NA
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➢ Total Area</li> <li>➢ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> </ul>	NA	NA	NA
		NA	NA	NA

N/16

	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

*Ajy*  
28/4/22

Signature of the Inspecting Officer  
Name **Ajay Kumar Sharma**  
Designation **ADO (Rohini)**

DO (NW)

*Ajy*  
26/04/2022  
*Ajy*  
26/04/2022

*Ajy*  
28/4/22

*Ajy*

*Ajy*  
29/4/22



*Ajy*  
29/04/22

*Ajy/Rohini*

FT letter is put up for kind perusal and  
Signature please

*Ajy*  
5/05/2022  
*Ajy*  
5/05/2022

*Ajy*  
14/5/22