

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No.F6/DFS/MS/SZ/2022/ School/490

Dated: 09/05/2022

**FIRE SAFETY CERTIFICATE**

Certified that the building Tiny Tulips School Located at Sector – 04, Dwarka, New Delhi - 110075 comprised of Ground + 02 Upper Floor, owned/occupied by Delhi Government was issued FSC vide Letter No. F.6/DFS/MS/School/2019/SZ/375 Dated 12/02/2019. The premises was re inspected by the officer concerned of this department on 19/04/2022 in the presence of Smt. Niva Deo (Principal) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class B "Educational building" with effect from 09/05/2022 for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/05/2022 at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service.

Copy to:

1. The Principal Tiny Tulips School Located at Sector – 04, Dwarka, New Delhi – 110075.
2. Directorate of Education Old Secretariat Delhi – 110054

**Following fire safety directives must be adhered to:-**

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/15  
**INSPECTION REPORT**

1. Name & address of the building: Tiny Tulips School Located at Sector – 04, Dwarka, New Delhi - 110075.
2. Type of Occupancy : Educational (Ground +02 Upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2019/SZ/1527 Dated 24/07/2019
5. Fire Safety directives Letter No. : Old case
6. Date of inspection : 19/04/2022
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer  
from the building side : Smt. Niva Deo (Principal)
9. Year of Construction : 2005 2<sup>nd</sup> floor 2015
10. Applicant's letter No. : Nil Dated – 08/04/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/13	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	12 mtr	MR
	• Gate width	4.5mtrs	Provided( Old Case)	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr & 0.75 m	Provided	MR old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	02	MR
	e. Width Of Corridor	1.5 m	1.80 m	MR
	f. Door Size	01 m	85 cm	MR (Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

10

N/116

N/116

5.	Fire Extinguishers			
	• Total numbers	02 nos.each floor	12 Nos.	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
		30 mtr	30 mtr	MR
	• Length of hose reel hose	5 mm	5 mm	MR
	• Nozzle diameter			
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	> Head of main pump	NA	NA	NA
	> Number of main pumps	NA	NA	NA
	> Jockey pump out put	NA	NA	NA
	> Jockey pump head	NA	NA	NA
	> Standby Pump out put	NA	NA	NA
	> Standby Pump Head	NA	NA	NA
	> Auto Starting/Manual stopping	NA	NA	NA
	> Pump House Access			
	• Terrace level	450 lpm	Provided	MR
	> Discharge of pump	30 mtr	Provided	MR
	> Head of the pump	Required	Provided	MR
	> Power supply	Required	Provided	MR
	> Auto starting of pump			
14	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	> Draw off connection	NA	NA	NA
	> Fire service inlet	NA	NA	NA
	> Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15	Exit Signage	Required	Provided	MR



N112

16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the Rules the NOC issued vide letter no. F.6/DFS/MS/School/2019/SZ/1527 Dated 24/07/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
 Name *Uday Vir Singh*  
 Designation *AD/DFCS*

*[Signature]*  
*28/11/22*

*[Signature]*  
*28/11/22*

*[Signature]*  
*29/11*

*[Signature]*  
*29/11*

*[Signature]*  
*29/11*

Since the letter is put up for sig plz  
*[Signature]*  
*25/11*

*[Signature]*  
*MS Cell*