

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2022/ School/491

Dated: 09/05/2022

**FIRE SAFETY CERTIFICATE**

Certified that the building of Vandana Kindergarten Located at Sector – 10, phase – 1, Dwarka, New Delhi - 110075 comprised of Ground + 02 Upper Floor, owned/occupied by Vandana Kindergarten was issued FSC vide Letter No. F.6/DFS/MS/School/2019/SZ/1137 Dated 28/05/2019. The premises was re inspected by the officer concerned of this department on 21/04/2022 in the presence of Sh. V. P. Tobdon (Chairman) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 under Delhi Fire Service Act 2007 and that the building is fit for occupancy class B "Educational building" with effect from 09/05/2022 for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/05/2022 at New Delhi by.



(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service.

Copy to:

1. The Principal Vandana Kindergarten Located at Sector – 10, phase – 1, Dwarka, New Delhi - 110075.
2. Directorate of Education Old Secretariat Delhi – 110054

**Following fire safety directives must be adhered to:-**

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

4/17  
**INSPECTION REPORT**

1. Name & address of the building: Vandana Kindergarten Located at Sector – 10, phase – 1, Dwarka, New Delhi - 110075.
2. Type of Occupancy : Educational (Ground +02 Upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2019/SZ/1137 Dated 28/05/2019
5. Fire Safety directives Letter No. : Old case
6. Date of inspection : 21/04/2022
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. V. P Tobdon (Director)
9. Year of Construction : 2011-2012
10. Applicant's letter No. : Nil Dated – 08/04/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/12	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	4.5mtrs	Provided( Old Case)	MR(Being Old Case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	02 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr each	Old Case	MR (Being old case )
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	01 No	MR
		1.5 m	1.60 m	MR
	e. Width Of Corridor	01 m	1m provided	MR
	f. Door Size			
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

10

N/18

4.	Smoke managements System • Basements • Upper floors	NA	NA	NA
		12 a/c charge per hour	Natural Ventilation	MR
5.	Fire Extinguishers • Total numbers • Types • IS marking	12 nos. ABC & CO <sub>2</sub> ISI marked	16Nos. Provided ISI marked	MR MR MR
6.	First – Aid Hose Reels • Total numbers on each floor • Length of hose reel hose • Nozzle diameter	01	01	MR
		30 mtr	30 mtr	MR
		5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10	Automatic Sprinkler System			
	• Basements • Upper Floor • Sprinkler above false ceiling	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants:			
	• Size of riser/down- comer • Number of hydrants per floor • Hose Box	100 mm	Provided	MR
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants • Hose Box	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements:			
	• Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm & 180 lpm	900 lpm	MR
		40 mtr	Provided	MR
		Required	Provided	MR
Required	Provided	MR		

4119

14	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric meter	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the Rules the NOC issued vide letter no. F.6/DFS/MS/School/2019/SZ/1137 Dated 28/05/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
 Name *Harvir Singh*  
 Designation *ADO/DNSP*

*DO/CO*  
*28/4/22*

*Dy SDO (SZ) F.F.*  
*[Signature]*

*AO (DNR)*