

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/NDZ/2022/ 209

Dated:- 12/05/2022

FIRE SAFETY CERTIFICATE

Certified that the **GMC Balayogi Auditorium** located at **Parliament Library building, New Delhi**. Library building is comprised of 02 basements + Gr. +1 upper floor and Auditorium is situated at 1st basement, ground & first floor, was earlier granted FSC by this department vide letter No. F6/DFS/MS/2010/2710 dated 17/09/2010. Now, the premises were re-inspected by the officers concerned of this department on 09/05/2022 in the presence of CPWD Officials Sh. Dharam Raj AE(E) & EE(E) and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Occupancy D-2 – Auditorium only** with effect from12/05/2022 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on12/05/2022 at New Delhi by.


11/5/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. The Executive Engineer, (E) Parliament Library building, CPWD Library Building, Pt. Pant Marg, New Delhi,

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration is prohibited. And use of basement shall be strictly as per BBL concerned.

101
INSPECTION REPORT

1. Name & address of the building:- GMC Balayogi Auditorium , Parliament Library
Parliament House Complex, New Delhi.
2. Type of occupancy:- Assembly occupancy
Library building is comprised of 2B+ Gr.+01 upper floor
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/2010/2710 dated 17.09.2010
5. Fire safety directives No.- F6/DFS/MS/1993/1007 dated 04/06/1993
6. Date of inspection:- 09/05/2022
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/ CD) &
Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Sh. Dharamraj (AE) & EE(E)
9. Year of construction:- 1993
10. Applicant's letter No:- No.23/ Fire /EE (E) /CPWD/2022/156 dated 04.05.2022

Renewa

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirements / Existing arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 nos	02 nos	MR
	2. Basements	02 nos	02 nos	MR
	B. Width of staircase			
	1. Upper floors	2.0 mtr. each	2.0 mtr. each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size (Audi)	6x1.50 mtr. & 4x1.5mt (UL)	6x1.50 mtr. & 4x1.5mt (UL)	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	08nos	10 nos	MR
	2) Types	ABC, CO2 & W. CO2	ABC, CO2 & W. CO2	MR
	3) ISI marking	ISI	Yes	MR

108

6.	First-Aid Hose Reel			
	1) Total number of each floor	02 Nos	02nos	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke/beam	Provided	MR
	2) Location of main panel	Ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Ground floor	Ground floor	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm.	100 mm.	MR
	2) Number of hydrants per floor	02nos Nos.	02 nos	MR
	3) Hose box at each floor	11 Nos.	11 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02Nos.	02 Nos.	MR
	2) Hose box	02Nos.	02 Nos.	MR
13.	Pumping Arrangement			
	2) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	55 mtr.	55 mtr.	MR
	c) Number of main pump	2 Nos.	2 Nos.	MR
	d) Jockey pump output	280 LPM	280 LPM	MR
	e) Jockey pump head	55 mtr.	55 mtr.	MR
	f) Stand by pump output	4500 LPM	4500 LPM	MR
	g) Stand by pump head	55 mtr.	55 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	3) Terrace level			
	a) Discharge of pump	900 lpm	900 lpm	MR
	b) Head of pump	25mt	25mt	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting Existing			
	1) Under ground tank capacity	2,00,000 ltrs.	2,00,000 ltrs.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	50,000 ltrs.	50,000 ltrs.	MR
15.	Exit Signage.	Required	provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A

19.	Fire Control Room	Required	Provided	MR
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any: flooding system on LT panel .			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection..

In view of the compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter No. F6/DFS/MS/2010/2710 dated 17/09/2010. Accordingly, FSC letter is prepared and put up for kind perusal, approval and signature please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

[Handwritten Signature]
11/5/22

[Handwritten Signature]
11/5/22

Name :- Rajinder Atwal
Designation :- DO (CD)

Name :- Ravinder Singh
Designation :- ADO (CC)

Dy. Chf (NDZ)

[Handwritten Signature]
11/5/22



ADO (CC)

[Handwritten text:] As approved peris put up for kind perusal and signature please.

Dy. Chf (NDZ)

[Handwritten Signature]
11/5/22

[Handwritten Signature]
11/5/22

SAS