

C/24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No. F.6/DFS/MS/School/2022/SZ/ 502

Dated. 09/05/2022

FIRE SAFETY CERTIFICATE

Certified that **St. Anthony's Sr. Sec. School** located at C-6, SDA Hauz Khas, New Delhi 110016 comprised of Four Blocks- Sr. Block & Primary Block- Ground plus 02 upper floors, Nursery Block-which was in School Boundary has been separated and one chapel & residential block- Ground plus One and Half upper floor but FSC was issued for Sr. & Primary Block by this department vide letter no. F6/DFS/MS/School/2019/SZ/774 dated 09/04/2019. The premises was re-inspected by officer concerned of this department on 29/04/2022 in presence of Mr. Basudevan and observed that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, with effect from the 09/05/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/05 /2022 at New Delhi by



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER

Copy to: -

1. St. Anthony's Sr. Sec. School located at C-6, SDA Hauz Khas, New Delhi 110016
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

M/S

INSPECTION REPORT

1	Name & Address of the Building	St. Anthony's Sr. Sec. School at C-6, SDA Hauz Khas, New Delhi 110016		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	School Building is in Four Blocks- Sr. Block & Primary Block- Ground plus 02 upper floors, Nursery Block-which was in School Boundary, has been separated and one chapel & residential block- Ground plus one upper floor and Half Floor. NOC issued for Sr. & Primary Block both are G+2		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2019/SZ/774 dated 09/04/2019		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	29-04-2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Basudevan		
10	Year of construction	1970		
11	Applicant letter No.	Outdoor diary no 370 dated 12-04-2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Sr. Block-02 Pry. Block-02	Sr. Blk-02 Nos Pry. Blk- 02 Nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5m / 0.75m	Sr. Block-1.75 mtr each Pry. Block-1.70m & 1.50m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	01 at each Blk Provided	MR
	e) Width of corridor	1.50 m	Provided	MR
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	20 Nos	20 Nos	MR
		ABC / CO2	ABC & Co2	MR

N/15

	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/School/2019/SZ/774 dated 09/04/2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Sh
21/5/2022

Signature of the Inspecting Officer
Name: Sh Rajesh Kumar
Design: ADO (BCP)

DO(SD) - on leave

De (F/S) 2

F.T.
Sh

ADO (BCP)

As approved, F.T. letter is pending for your signature pl

F.S.

1/14/6/15

DO (F/S) 2

Sh

ADO (BCP)

M-S. al