

FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/ EH/121

Dated: 11/05/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Café after hours (A unit of LKG Hospitality Pvt Ltd.) Located at Shop no 122-130, First floor City Centre Mall, Sector - 12, Dwarka New Delhi., in a building comprised of 02 Basement + Ground + 05 Upper Floors **was issued FSC vide Letter No: F6/DFS/MS/EH/2019/SZ/556 Dated 15/03/2019 (FSC issued to mall vide letter no F6/DFS/MS/SZ/2022/158 Dated 12/04/2022)** The premises was re inspected by the officer concerned of this department on 27/04/2022 in the presence of Sh. Pankaj Joshi (Manager) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly" Group D (**First Floor**) with effect from 11/05/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 11/05/2022 at New Delhi by.

(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, N Delhi.
2. Pankaj Joshi (Manager) M/s Café after hours (A unit of LKG Hospitality Pvt Ltd.) Located at Shop no 122-130, First floor City Centre Mall, Sector - 12, Dwarka New Delhi.
3. DHO, Naya Ghar Zone, SDMC, public health department, Room No-408, Zonal office, Following fire safety directives must be adhered to:- building, Near. Dhansa, Stand N Delhi

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

14/12
INSPECTION REPORT

1. Name & address of the building: M/s Café after hours a unit of LKG Hospitality Pvt Ltd. Located at Shop no 122-130, First floor City Centre Mall, Sector – 12, Dwarka New Delhi.
2. Type of Occupancy : Class-D (Assembly) **(At First Floor in the Mall)**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2019/SZ/556 Dated 15/03/2019
F6/DFS/MS/SZ/2022/158 Dated 12/04/2022(Issued to Mall)
5. Fire Safety directives L. No. :F6/DFS/MS/BP/2012/4026 Dated 26/10/2012 **(issued to mall)**
6. Date of inspection : 27/04/2022
7. Name of the Inspecting Officer ; ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Pankaj Joshi (Manager)
9. Year of Construction . 2015
10. Applicant's letter No. : 2022040505544 dated 16/04/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/6	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 mtrs	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits(Common With Mall)			
	a. Number of staircases			
	• Upper floors	02 nos	Provided (by Mall)	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02 nos	Provided	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	2x 2m	Provided (Old case)	MR
3.	Compartmentation(Common With Mall)			
	• Fire check door	NA	Provided	NA
	• Sealing of electrical shafts	NA	Provided	NA
	• Fire Rating of shaft door	NA	Provided	NA
	• Water Curtain	NA	Provided	NA
	• Fire Dampers	NA	Provided	NA

25

4/13

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	5 nos. each type	Provided	MR
	• Types	ABC, CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reel	Common with mall		
	• Total numbers on each floor	Required	Provided by Mall	MR
	• Length of hose reel hose	36 m	Provided by Mall	MR
	• Nozzle diameter	5 mm	Provided by Mall	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	Provided	NA
	• Location of Main Panel	NA	Provided	NA
	• Location of Repeater Panel	NA	Provided at ground floor	NA
	• Alternate source of power	NA	Battery backup	NA
	• Hooters' Location	NA	Near staircase at all floors	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System (Common with mall)			
	• Basements	NA	Provided	NA
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants: (common with the mall)			
	• Size of riser/down- comer	100 mm	Provided by Mall	MR
	• Number of hydrants per floor	Required	Provided by Mall	MR
	• Hose Box	Required	Provided by Mall	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	Provided by Mall	NA
	• Hose Box	NA	Provided by Mall	NA
13.	Pumping Arrangements: Common with Mall			
	• Ground Level			
	• Discharge of main pump	NA	2850 Lpm	NA
	➤ Head of main pump	NA	88 mtr	NA
	➤ Number of main pumps	NA	02 Nos.	NA
	➤ Jockey pump out put	NA	280 Lpm	NA
	➤ Jockey pump head	NA	88 mtr	NA
	➤ Standby Pump out put	NA	2850 Lpm	NA
	➤ Standby Pump Head	NA	88 mtr	NA
	➤ Auto Staring/Manual stopping	NA	Provided By Mall	NA
	➤ Pump House Access	NA	Provided By Mall	NA
	• Terrace level	450 lpm	Provided	MR
	➤ Discharge of pump	40 m	Provided	MR
	➤ Head of the pump	Required	Provided	MR
	➤ Power supply			
	➤ Auto starting of pump	Required	Provided	MR

4/13

N/14

14.	Captive water Storage for fire fighting: Common with Mall			
	• Under ground tank capacity	NA	1.00,000 (By Mall)	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	10, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts Common with Mall			
	➤ Pressurization of Lift Shaft	NA	Provided	NA
	➤ Pressurization of lift lobby	NA	Provided	NA
	➤ Communication in lift Car	NA	Provided	NA
	➤ Fireman's Grounding Switch	NA	Provided	NA
	➤ Lift Signage	NA	Provided	NA
17.	Standby power supply	Required	Provided By Mall	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room(Common with Mall)			
	➤ Detector system panel	NA	Provided	NA
	➤ Flow Switch Panel	NA	Provided	NA
	➤ PA System Panel	NA	Provided	NA
	➤ Battery backup	NA	Provided	NA
	➤ Building Floor Plans	NA	Provided	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided By Mall	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/EH/2019/SZ/556 Dated 15/03/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

11/29/4/22

Signature of the Inspecting Officer
Name UdaiVir Singh
Designation ADO/DWK

DO/Sa
4/5/22
Degeo (S/2)
F. It
A DO/DWK

Sir Pt letter is put up for sign ble

Degeo/132

M.S. cell

10/5/22