

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/School/2022/NDZ/ 513

Dated: 12/05/2022

FIRE SAFETY CERTIFICATE

Certified that the Little Flowers International School at C-11, 12, 100 Feet Road, Kabir Nagar, Shahdara, Delhi -110094, comprised of Basement, ground plus two upper floors (old building) & ground plus two upper floors (New building) owned/occupied by Little Flowers International School was issued FSC vide letter No. F6/DFS/MS/School/2019/NDZ/414 dated 14/02/19. The school buildings were re-inspected by the officer concerned of this department on 20/04/2022 in the presence of Mr. R.K. Dua, Chairman of the school and found that the school building have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the school buildings is fit for Basement, ground plus two upper floor & stilt, upper ground plus two upper floor occupancy class 'Educational Building' (Group B) with effect from 12/05/2022 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 12/05/2022 at New Delhi by

  
12/5/22

(Dr. S.k Tomar)  
Dy.Chief Fire Officer

To,

The Chairman,  
Little Flowers International School,  
C-1,12, 100 feet  
Road, Kabir Nagar,  
Shahdara, Delhi -110094.

Copy:-

The Dy. Director of Education  
B-Block, Yamuna Vihar,  
Delhi-110053.

**CONDITIONS**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. Basement shall be used as per BBL.

or 123

1. Name & address of the building : Little Flowers International School,  
C-11, 12(100 feet road), Kabir Nagar, Delhi-110094,
2. Building is comprised of : Old Building (B+G+2) & New Building (G+2)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/School/2019/NDZ/414 dated- 14/02/19
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 20/04/2022
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of Officer  
from the building side : Mr. R.K Dua, (Chairman)
10. Year of Construction : Old Building 2005-2006 & New Building 2015
11. Applicant's letter No : Email Dated- 10/02/22

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV /BBL Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	15 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02 old Bldg 01 + 01 EE (New bldg)	03 old bldg 02 new bldg	MR
	• Basement	02 nos.	04 nos.	MR
	b. Width of Staircases			
	• Upper floor	1.50 mtr.+ 1.50 mtr	1.01 mtr, 1.05 mtr, 01 mtr old bldg & 01 mtr & 1.52 mtr new bldg	MR
	• Basement	1.50 mtr.	1.01 mtr, 1.05 mtr, 01 mtr & 01 mtr.	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 Nos. (in each floor)	01 Nos. (In each floor)	MR
	e. Width of Corridor	1.50 mtr.	1.50 mtr each	MR
	f. Door Size	01 mtr.	01 mtr	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	20 nos.	20 nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR

or 123

or 123



02/24


06	First-Aid-Hose Reels.			
	Total numbers on each floor (old & New Building)	01 No + 01 No.	01 No + 01 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA			
09	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump each block	900 lpm	900 lpm+450 lpm	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	15,000 Ltr.	15,000 Ltr.	MR
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A

17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection system provided in the building were tested/checked at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required as per NBC Part IV, it is recommended to renew Fire Safety Certificate Under the rule 35 of Delhi Fire Service rules 2010.

Signature of the Inspecting Officer  
Name :- Mehmood  
Designation :- A.D.O (TP)



~~DOED~~ 21/4/2022

By C.F.O. (N.D.2)

Pl. speak

22/4/22

~~DOED~~ 25/04/2022

Adopt. P. spoken  
In. R. Sub. will be taken

By R.O. (N.D.2)

29/5/22  
DOED (TP)

11/5/22  
Adopt. P. A.C.T. letter put up for signature

By R.O. (N.D.2)

12/5/22

12/5/22  
DOED (TP)