

C/26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.F6/DFS/MS/School/2022/SZ/515

Dated: 12/05/2022

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya, Rajouri Garden Extn. New Delhi, Comprised of ground plus three upper floors (New Block), owned/occupied by Sarvodaya Kanya Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with the Rules 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 27/04/2022 in the presence of **Sh. Karnail Singh** and found that the school building is fit for occupancy class B 'Educational Building' for with effect from 12/05/2022 for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....12/05/2022.....at New Delhi by


(Atul Garg)
Director
Delhi Fire Service
900

Copy to:-

1. The Principal, Sarvodaya Kanya Vidyalaya, Rajouri Garden Extn. New Delhi.
2. The Executive Engineer (E) Division, ITI Campus Pusa, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, Rajouri Garden Extn.
New Delhi.
2. Building is comprised of : G+3 upper floors. (New block)
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of Previous FSC letter : Nil
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 27/04/2022
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer:
From the building side : Sh. Karnail Singh
10. Year of Construction : 2018-22
11. Applicant's letter No. : 54 (SPS School) PWD Edu. Sub-Divn M1-1(N)/2022-23/Camp (01) Dated- 08/04/2022

S. N	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 m.	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	04 Nos.	04 Nos.	MR
		N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.50 m each	2X1.8 & 2X1.7M	MR
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 No.	02 No.	MR
	e. Width of Corridor	1.5 m.	1.7 m.	MR
	f. Door Size	1.20 m	2X1.20 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A	N/A	N/A
		Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types 	12 nos.	Provided	MR
		ABC /CO ₂	ABC /CO ₂	MR
	<ul style="list-style-type: none"> • IS marking 	IS I marked	ISI marked	MR

0	First-aid-Hose Reels.	Total numbers of each floor	05 Nos.	Provided	MIR
		• Length of hose reel hose	30 m	Provided	MIR
		• Nozzle diameter	05mm	Provided	MIR
7	Automatic fire detection and alarming system.	Type of detectors	N/A	N/A	N/A
		• Location of main panel	N/A	N/A	N/A
		• Location of repeater panel	N/A	N/A	N/A
		• Alternate source of power	N/A	N/A	N/A
		• Hooper's location	N/A	N/A	N/A
8	MOEFA		N/A	N/A	N/A
9	Public address System.		N/A	N/A	N/A
10	Automatic Sprinkler System.	Basement	N/A	N/A	N/A
		• upper floor	N/A	N/A	N/A
		• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	size of riser/down-corner	N/A	N/A	N/A
		• Number of hydrants per floor	N/A	N/A	N/A
12	Yard Hydrants.	Hose Box	N/A	N/A	N/A
		• Total number of hydrants	N/A	N/A	N/A
		• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	Discharge of main Pump	N/A	N/A	N/A
		• Ground Level	N/A	N/A	N/A
		• Discharge of main Pump	N/A	N/A	N/A
		• Head of Main Pump	N/A	N/A	N/A
		• Number of main pumps	N/A	N/A	N/A
		• Jockey pump out put	N/A	N/A	N/A
		• Jockey pump head	N/A	N/A	N/A
		• Standby pump out put	N/A	N/A	N/A
		• Standby pump Head	N/A	N/A	N/A
		• Auto Starting /Manual stopping	N/A	N/A	N/A
		• Pump House Access	N/A	N/A	N/A
		• Terrace Level	N/A	N/A	N/A
		• Discharge of pump	450 LPM	2X900 LPM	MIR
		• Head of the Pump	40 M	Provided	MIR
		• Power supply	Required	Provided	MIR
		• Auto Starting of pump	Required	Provided	MIR
14	Captive Water Storage for Fire Fighting.	Underground tank capacity	N/A	N/A	N/A
		• Draw-off connection	N/A	N/A	N/A
		• Fire service inlet	N/A	N/A	N/A
		• Access to tank	N/A	N/A	N/A
		• Overhead Tank capacity	10,000 Ltr.	10,000 Ltrs	MIR
15	Exit Signage.	Required	Required	Provided	MIR

0/14

415

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety as required under the Rule 35 of the Delhi Fire Service Rules 2010 it is recommended to grant Fire Safety Certificate.

R.K. Yadav
28/4/2022

Signature of the Inspecting Officer
Name- R.K. Yadav
Designation- A.D.O(JKP)

DO(South West) *W*
28/4/2022

Dycto (S/W)
A
29/4

C/O
Director
9/5/2022
9/05/2022

R.K. Yadav