

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/Petrol/2022/SZ/ 214

Dated: 13/05/2022

FIRE SAFETY CERTIFICATE

Certified that M/s Welcome Motors (Storage of IOCL, Petroleum Products) located at Mandir Marg, District Centre, Saket, New Delhi 110017 comprised of Ground floor only owned/occupied by M/s Welcome Motors was issued FSC by this department vide letter No. F6/DFS/MS/Petl./2018/SZ/2290 Dated 10/10/2018. The premises was re-inspected by the officer concerned of this department on 07/05/2022 in the presence of Mr. Anurag Mishra (in-charge) of the said filling station and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group-J, Hazardous Building** as above with effect from 13/05/2022 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 13/05/2022 at New Delhi by

(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. M/s Welcome Motors (Storage of IOCL, Petroleum Products) located at Mandir Marg, District Centre, Saket, New Delhi 110017.
2. The Administrative Officer, South Zone, South MCD, Green Park, New Delhi-110016.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any deviation, with regard to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

N/18

INSPECTION REPORT

1	Name & Address of the Building	M/s Welcome Motors (Storage of IOCL Petroleum Products) Mandir Marg, District Centre, Saket, Delhi		
2	Type of Occupancy	Hazardous Building (Group-J)		
3	Building Comprised of	Single storey building		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Petrol/2018/SZ/2290 Dated 10/10/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	07-05-2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Anurag Mishra		
10	Year of construction	1981		
11	Applicant letter No.	Outdoor dairy no 7467 Dated 22-05-2022		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Required -NA- -NA-	09 mtr -NA- -NA-	MR -NA- -NA-
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	b. Width of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d. No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	1 m	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	-NA- -NA-	-NA- -NA-	-NA- -NA-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	31 Nos ABC/CO2/DCP Required	Provided CO ₂ (4.5 kg) ABC & Foam Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-

7	Automatic Fire Detection and Alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump.	-NA-	-NA-	-NA-
	➤ Head of pump.	-NA-	-NA-	-NA-
	➤ Power supply.	-NA-	-NA-	-NA-
	➤ Auto starting of pump.	-NA-	-NA-	-NA-
14.	Captive water storage for fire-fighting.			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	-NA-	-NA-	-NA-
15.	No Smoking Signage (Hindi & English)	Required	Provided (Hindi & English)	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	NA	-NA-
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

N/20

19.	Fire Control Room.			
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	1. Provided fire buckets filled with loose electrical wiring. 2. No loose electrical wiring seen in the retail outlet area.		MR

The fire protection system such as fire extinguisher of different type and capacity, Fire buckets filled with loose dry sand & water provided at suitable places in the retail outlet area were checked and found functional at the time of inspection. "No Smoking" sign board were found displayed both Hindi & English at conspicuous places. No loose electrical wiring was seen in the premises.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under rules, renewal of the FSC issued vide letter No. F6/DFS/MS/Petrol/2018/SZ/2290 Dated 10/10/2018, under rules 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer
 Name: Sh. Rajesh Kumar
 Designation: ADO(BCP)

Sh. Rajesh Kumar
 11/5/2022

DO (SD)

Ring
 10/05/22

DFO (SD)

IE

[Signature]

ADO (B/P)

As approved, F.T. letter is put up for your signature

11/5/2022

Dy 10/5/22

[Signature]

MS. all