

C-76

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2022/ EH/S2/126

Dated 13/05/2022

FIRE SAFETY CERTIFICATE

Certified that the building of Pinch of Spice MNC Hospitalities Mocktails N Cocktails LLP Located at 3rd floor, plot no-18 Wadhwa Plaza-III, Central Market, Sector-10, Dwarka, New Delhi.110075 in a building comprised of Ground + 3 Upper Floors owned/ occupied by MNC Hospitalities Mocktails N Cocktails LLP was issued FSC vide Letter No F6/DFS/MS/EH/SZ /2019/913 dated 29/04/2019 (**Issued to Godawari Restaurant earlier running in the same premises**).The premises was re inspected by the officer concerned of this department on 28/04/2022 in the presence of Sh. Umesh Sharma and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class " Assembly" Group D with effect from 13/05/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/05/2022 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Joint. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Manager, Pinch of Spice MNC Hospitalities Mocktails N Cocktails LLP Located at 3rd floor, plot no-18 Wadhwa Plaza-III, Central Market, Sector-10, Dwarka, New Delhi.110075.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement strictly shall be kept vacant as seen during inspection.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/23
INSPECTION REPORT

1. Name & address of the building: Pinch of Spice MNC Hospitalities Mocktails N Cocktails LLP Located at 3rd floor, plot no-18 Wadhwa Plaza-III, Central Market, Sector-10, Dwarka, New Delhi.110075
2. Type of Occupancy : Class-D (Assembly)(**Running At 3rd Floor in a building comprised of Ground + 03 Upper Floors**)
3. Type of Case : Renewal
4. Details of previous NOC :F6/DFS/MS/EH/2019/SZ/913 Dated 29/04/2019 (**Issued to M/S Godawari Restaurant earlier running in same premises**)
5. Fire Safety directives Letter No. :Old case
6. Date of inspection : 28/04/2022
7. Name of the Inspecting Officer ; Sh. Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Sumit Sharma & Umesh Sharma
9. Year of Construction : Before 2005
10. Applicant's Letter No: Email Dated-04/04/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/17	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	01	MR(Being Old case)
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.25 mtr	1.20 mtr	MR(Being Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	01	MR
	e. Width Of Corridor	1.42 m	1.42 mtr	MR
	f. Door Size	Old Case	1.22 & 1M	MR(Being Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

17/28

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural Vent	MR
5.	Fire Extinguishers			
	• Total numbers	04 Nos.	08 Nos.	MR
	• Types	ABC, CO2	ABC, CO2	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reel			
	• Total numbers on each floor	01 No	Provided	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	One	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm & 180 lpm	Provided	MR
	➤ Head of the pump	30 m	30 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

14.	Captive water Storage for fire fighting:			NA
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	MR
	• Overhead Tank capacity	10000 ltr	Provided	MR
15.	Exit Signage	Required	Provided	
16.	Provision of Lifts			NA
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	MR
17.	Standby power supply	Required	Provided	
18.	Refuge Area			NA
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			NA
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.
 In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/EH/SZ/2019/913 dated 29/04/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name: *Uday Vora*
 Designation: *AD/D/2014*

AD/D/2014
4/5/22
K.F.
AD/D/2014 (DWR)
 Six PP letter is put up for sig ble
AD/D/2014
M.S. - 11
18/5/2022