

13/c

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS /School/2022/ 525

Dated: 17/05/2022

FIRE SAFETY CERTIFICATE

Certified that the **Gobind Ram Gurukul Secondary School** located at **Ram Bagh, Old Rohtak Road, Delhi-110007** comprised of **Ground Floor Only** owned/ occupied by **Gobind Ram Gurukul Secondary School** was issued Fire Safety Certificated vide this office letter no. **F6/DFS/MS/2019/WZ/469** dated **06.03.2019**. The premises was re-inspected by the officer concerned of this department on **06.05.2022** in the presence of **Mr. D.N. Kaushik (Administrative)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from 17/05/2022 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 17/05/2022 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-25156707

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, Gobind Ram Gurukul Secondary School located at Ram Bagh, Old Rohtak Road, Delhi-110007.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doiit/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

- 1 Name & address of the building : Gobind Ram Gurukul Secondary School, Ram Bagh, Old Rohtak Road, Delhi-110007.
2. Type of Occupancy : Educational
3. Composition of building : Ground floor only
- 4 Type of Case : Renewal
- 5 Details of previous NOC : F6/DFS/MS/2019/WZ/469 Dated: 06.03.2019
- 6 Fire Safety directives letter No : Director of Education Letter dated 01.03.2011
- 7 Date of inspection : 06.05.2022
- 8 Name of the Inspecting Officers : ADO (RN)
- 9 Name and designation of officers
from the building side : Mr. D.N. Kaushik (Administrative)
10. Year of Construction : 2006
11. Applicant's letter No. : letter no.GRG/2022-23/485 dated 21.04.2022

Plot Area- 5733 sq.m Covered Area:2309 sq.m class rooms -12+4 nos

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6m	MR
	• Gate width	4.5m	4.m	MR(old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			

	• Total numbers	5nos	06 nos	MR
	• Types	ABC/Co2	ABC-06	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
		NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA

17/11/20

1/12/21

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A
		N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no.469 dated 06.03.2019.

DO (HW)

09/05/2022

By CRO (W2)

[Handwritten signature]

Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN

ADO/RN

As approved, F.S. letter is put up for your signature Pl.

By CRO (W2)

[Handwritten signature]

09/05/2022

msf/cep