

C/31

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ2022/School/592

Dated: 13/05/2022

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Co -ed. Secondary School (New Block) Located at Sector - 16 A, Dwarka, New Delhi - 110078, comprised of G+03 Upper Floors owned/ occupied By Govt. Co -ed Senior Secondary School have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 04/05/2022 in the presence of Dr. Poonam (HOS) and found that the said building (New Block) is fit for occupancy class "Educational" Group B Sub Division B - 1 with effect from 13/05/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...13/05/2022... at New Delhi.

  
(Atul Garg)  
Director

Delhi Fire Service.

**Note: - The FSC is valid for new block comprised of Ground plus 03 Upper Floors.**

Copy to:

1. The Principal Govt. Co -ed. Secondary School Located at Sector - 16 A, Dwarka, New Delhi - 110078 . (School ID-1821242)
2. Directorate of Education Old Secretariat Delhi - 110054

**Following fire safety directives must be adhered to:-**

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/24

**INSPECTION REPORT**

1. Name & address of the building: Govt. Co -ed. Secondary School Located at Sector - 16 A, Dwarka, New Delhi - 110078.(School ID-1821242)
2. Type of Occupancy : Educational (Ground + 03 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : . NBC
6. Date of inspection : 04/05/2022
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer  
from the building side : Dr. Poonam (HOS)
9. Year of Construction : 2022
10. Applicant's letter No. : 54(SPS School)/PWD Edu. Sub- Divn M1-1 (N)/2021-22/8 Dated 28/02/2022 Email Dated - 29/04/2022

No. of Students=640
No. of class rooms=17
Plot area=
Covered area=2091sqmtr

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/UBBL	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	Accessible	provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	2x180cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	150cm	165 cm	MR
	f. Door Size	120cm	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	NA Required	NA Natural ventilation	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	13 nos. ABC & CO <sub>2</sub> ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	02 Each floors 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA NA NA	NA NA NA	NA NA NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA

13	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000Ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

1197

20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer  
 Name Uday Vir Singh  
 Designation ADDP/1307

DOP/120  
16/5/22

Dy CFO (S2)  
10/5

CFO  
11/5/2022  
Director  
11/5/22

12/5/22

Since RT letter is not of the subject

Director  
13/5/2022  
mu

12/5