

DFM
C-95

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/WZ/2022/ 517

Dated: 12/05/2022

FIRE SAFETY CERTIFICATE

Certified that the **Govt. (Co-ed) Senior Secondary School, Sultanpur Majra, Delhi-83. (School ID-1412016)** comprised of **02 blocks, A & B blocks, Ground + 03 upper floors** owned/occupied by **Govt. (Co-ed) Senior Secondary School** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on dated **28.04.2022** in the presence of **Er. Shashank Sahu (AE)** and that the building/ premise is fit for occupancy '**Group B Educational**' with effect from 12.05.2022 for a period of **three years**, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/05/2022 at New Delhi by


(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to:

1. The Principal, Govt. (Co-ed) Senior Secondary School, Sultanpur Majra, Delhi-83. (School ID-1412016).
 2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054
- etc
om

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Govt. (Co-ed) Senior Secondary School, Sultanpur Majra, Delhi-83
2. Type of Occupancy : Educational (School ID-1412016)
3. Type of Case : New Case (02 Blks. A & B Blocks, Ground + 03 upper floors)
4. Details of Previous NOC : N/A
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 28.04.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Er. Shashank Sahu
9. Year of Construction : 2021
10. Applicant's letter No. : Online e-mail dated 25.04.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6.0m	Provided	MR
		4.5m	Provided	MR
		NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors 	A-Blk-03 B-Blk-02	A-Blk-03 B-Blk-02	MR MR
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	e. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	A-Blk-1.5m B-Blk-1.5m	A-Blk-1.5m B-Blk-1.5m	MR MR
		NA	NA	NA
	f. Protection of exits			
	Fire check door	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	A-Blk-03 B-Blk-02	A-Blk-03 B-Blk-02	MR MR
	e. Width of Corridor	A-Blk-1.5m B-Blk-1.5m	A-Blk-1.70m B-Blk-1.70m	MR MR
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	A-Blk-30 B-Blk-22	A-Blk-104 B-Blk-104	MR MR
		ABC/CO2	ABC-104/CO2-104	MR
		ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	A-Blk-03 B-Blk-02	Provided Provided	MR MR
		30mm	Provided	MR
		5m	Provided	MR
7.	Automatic fire detection and alarming system			

2/19

	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Ajay
2/5/22

Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO (Rohini)**

~~DO (NW)~~

Ajay
09/05/2022

[Signature]
10/5/2022

Dy. C/O (W2)

~~Director~~

[Signature]
11/05/22

Ajay Rohini

FT letter is put up for kind and signature please.

~~Director~~
[Signature]
12/05/22

Ajay
4/5/22

[Signature]