

C-25

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/NDZ/ 466

Dated: 27/4/2022

**FIRE SAFETY CERTIFICATE**

Certified that the Bharat National Public School at 54, Mahila Colony, Gandhi Nagar, Delhi-110031, comprised of ground plus one upper floor owned/occupied by Bharat National Public School was issued FSC vide letter No. F.6/DFS/MS/School/2019/NDZ/220 dated 29/01/2019. The premises was re-inspected by the officer concerned of this department on dated 04/04/2022 in the presence of Ms. Shanta Grover, In-charge of the school and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational Building (Group-B)' with effect from 27/4/2022 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on ..... 27/4/2022 ..... at New Delhi by

  
27/4/22

**(Dr. S. K. Tomar)**  
**Dy. Chief Fire Officer**

To,  
The Principal,  
Bharat National Public School,  
54, Mahila Colony, Gandhi Nagar, Delhi-110031

Copy:-  
The Director of Education, EDMC  
Plot No. 18-24, Udyog Sadan, Patparganj Industrial Area, Delhi-110092

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

N/12

1. Name & address of the building : Bharat National Public School,  
54, Mahila Colony, Gandhi Nagar, Delhi-110031
2. Building is comprised of :Groundplus one upperfloor
3. Type of Occupancy :Educational
4. Type of Case :Renewal
5. Details of Previous NOC letter :F.6/DFS/MS/School/2019/NDZ/220dated-29/01/19
6. Fire Safety direction letter No :F16/Estate/CC/FireSafety/2011/3298to3398 dt-01/03/11
7. Date of Inspection : 04/04/2022
8. Name of the Inspecting officers :ADOD Deepak Kumar
9. Name and designation of Officer  
from the building side : Ms. Shanta Grover, In-charge
10. Year of Construction :2010
11. Applicant's letter No :BPNs/2022 dated 28/12/2022 received on  
dated – 02/03/2022

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	DoE Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	• Road width	06mtr.	06mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 nos.	02 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 mtr.	01 mtr & 0.80 mtr (Iron)	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases tototerrace	01 no.	01 no.	MR
	e. Width of Corridor	1.50 mtr.	1.50 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A

e. 

N/13

05	Fire Extinguishers			
	• Total numbers	04nos	04nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main Pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby pump out put	N/A	N/A	N/A
	➢ Standby pump Head	N/A	N/A	N/A
	➢ Auto Starting /Manual stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➢ Discharge of pump	N/A	N/A	N/A
	➢ Head of the Pump	N/A	N/A	N/A
	➢ Power supply	N/A	N/A	N/A
	➢ Auto Starting of pump	N/A	N/A	N/A

2. 

N/14


16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The shortcoming issued vide letter no. F.6/DFS/MS/School/2021/NDZ/686 dated 28/12/2021 have been rectified .

Keeping in view of the non compliance of the minimum standards of fire prevention and fire safety required under the rules the FSC issued vide latter No. F.6/DFS/MS/School/2019/NDZ/220dated-29/01/19 renewal under rule 35 of The Delhi Fire Services rules 2010 is recommended.

*Deepak*  
20/04/2022  
(DEEPAK KUMAR)  
ADO (Shahdara)

DO (ED) *AKB*  
20/4/2022



*DRCFOT (NDZ)*  
*AKT/mm*  
22/4/22

*ADO (Shahdara)*  
Sir,

F.T. letter is put for your signature please .

*Deepak*  
25/04/2022