

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F.6/DFS/MS/School/2022/SZ/547

Dated: 20/05/2022

FIRE SAFETY CERTIFICATE

Certified that the High Rise Pubic School, K-4/36-39, Mohan Garden, Uttam Nagar, New Delhi-110059, comprised of ground plus two upper floors, owned/occupied by High Rise Pubic School have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 26/04/2022 in the presence of Sh. Virat Rajput and found that the building is fit for occupancy 'Group B "Educational Building"' with effect from 20/05/2022 for a period of **three** years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....20/05/2022.....at New Delhi by


(Atul Garg)
Director

Delhi Fire Service

To,

The Manager,
High Rise Pubic School, K-4/36-39, Mohan Garden,
Uttam Nagar, New Delhi-110059.

Copy to:-

The Director of Education, Govt of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/G

INSPECTION REPORT

1. Name & address of the building : High Rise Pubic School, K-4/36-39, Mohan Garden, Uttam Nagar, New Delhi-110059.
2. Building comprised of : G+2 Upper floors
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC : N/A
6. Fire Safety directives letter No : NBC Part -IV
7. Date of inspection : 26/04/2022
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Virat Rajput
10. Year of Construction : Before 2006
11. Applicant's letter No. : 4Nil dated 20/03/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible (06 mtrs.) N/A N/A	Provided Directly accessible from road N/A	MR N/A N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 no.'s N/A	Provided N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 M & 1.35m N/A	1.60 & 1.35 to 1.46 m N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	02 no.'s	Provided	MR
	e. Width of Corridor	1.50 M	1.50 M	M/R
	f. Class Room Door Size	1.0 M	1.20 M	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation provided	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R

N/D

6.	First-Aid Hose Reels	• Total numbers on each floor	One	Provided	M/R
		• Length of hose reel hose	30 mtrs	Provided	M/R
		• Nozzle diameter	5 mm	Provided	M/R
7.	Automatic fire detection and alarming system				
	• Type of detectors	N/A	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A	N/A
10.	Automatic Sprinkler System				
	• Basement	N/A	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A	N/A
11.	Internal Hydrants				
	• Size of riser/down-comer	N/A	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A	N/A
12.	Yard Hydrants				
	• Total number of hydrants	N/A	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A	N/A
13.	Pumping Arrangements				
	• Ground Level				
	➤ Discharge of main Pump	N/A	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A	N/A
	• Terrace level				
	➤ Discharge of pump	450 LPM	Provided	M/R	M/R
	➤ Head of the pump	40 mtrs	Provided	M/R	M/R
	➤ Power Supply	Required	Provided	M/R	M/R
	➤ Auto Starting of pump	Required	Provided	M/R	M/R
14.	Captive Water Storage for fire fighting				
	• Underground tank capacity	N/A	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltrs	Provided	M/R	M/R
15.	Exit Signage.	Required	Provided	MR	MR

8

Provision of Lifts		No Lift		
<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	> Total Area	N/A	N/A	N/A
	> Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found not functional at the time of inspection.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures under Rule 35 of the Delhi Fire Service Rules 2010 it is recommended to grant Fire Safety Certificate.

R. K. Yadav

Signature of Inspecting Officer
 Name:- R.K.Yadav
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

W/S
28/1/20

28/1/20

6/5

CFO
W/S
9/5/2020

Director
1/5/20

Asstt. D.O.