

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2022/SZ/545

Dated: 19/05/2022

FIRE SAFETY CERTIFICATE

Certified that the **New Sainik Sr. Sec. Public School**, Qutub Vihar, Phase-I, P.O-Goyala Dairy, New Delhi-110071, comprised of partial basement, ground floor plus three upper floors owned/occupied by New Sainik Sr. Sec. Public School was issued Fire Safety Certificate vide letter no. F.6/DFS/MS/school/2019/SZ/1038 dated 16/05/2019. The school building was re-inspected by the officer concerned of this department on 26/04/2022 in the presence of Sh. Hare Krishna Singh (Chairman) and found that School building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....19/05/2022..... at New Delhi.

(SUNIL CHAUDHARY)
DY.CHIEF FIRE OFFICER

Copy to:-

1. The Manager,
New Sainik Sr. Sec. Public School, Qutub Vihar,
Phase-I, P.O-Goyala Dairy, New Delhi-110071.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

11

INSPECTION REPORT

Name & address of the building : New Sainik Sr. Sec. Public School, Qutub Vihar, Phase-I, P.O-Goyala Dairy, New Delhi-110071

Building comprised of : Partial basement, ground floor plus three upper floors (school is constructed in two phases New Blk & Old Blk interconnected with each other)

3. Type of Occupancy : Educational

4. Type of Case : Renewal

5. Details of Previous NOC : F6/DFS/MS/School/2019/SZ/1038 dated 16/05/2019

6. Fire Safety directives letter No : N/A

7. Date of inspection : 26/04/2022

8. Name of Inspecting Officer : A.D.O. R.K.Yadav

9. Name and designation of officers
From the building side : Sh. Hare Krishna Singh (Chairman)

10. Year of Construction : Before 2009 (GF) & 2014 (Old Block) & Before 2018 (New Block)

11. Applicant's letter No. : Outdoor diary no. 145 dated 06/04/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL-16 requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 m 4.5 m N/A	Provided Provided N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	03 no.'s 02 no.'s	04 no.'s provided Provided	M/R MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 m 1.50 m	1.60, 1.60, 1.55 & 1.35 m 1.50 m each	M/R M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Provided	M/R
	e. Width of Corridor	1.50 m	2.60 m	M/R
	f. Classroom Door Size	1.0 m in old bldg. & 1.20 m in New bldg.	1.0 m in Old bldg. & 1.20 m (double doors) in New Bldg.	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	Required Required	Provided Natural ventilation provided	M/R M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R

N/12

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Two 30 m 5 mm	Provided	M/R
			Provided	M/R
			Provided	M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		450 LPM (02 no.'s)	Provided	M/R
		40 m	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		15000 ltrs	Provided	M/R
15.	Exit Signage.	Required	Provided	M/R

Provision of Lifts.
Pressuriz
Co

17.

96

10/13

Provision of Lifts.		No Lift		
M/R	• Pressurization of Lift Shaft	N/A	N/A	N/A
M/R	• Pressurization of Lift lobby	N/A	N/A	N/A
M/R	• Communication In lift Car	N/A	N/A	N/A
N	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No.F.6/DFS/MS/school/2019/SZ/1038 dated 16/05/2019, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of Inspecting Officer R.K. Yadav 28/4/2022
 Name:- R.K.Yadav
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

28/4/22

DYCF0(\$2)

ch

10/13

at 10/13

F T helter - put up for sign please

DYCF0(\$2)

ch

11.5.00

R.K. Yadav 24/5/2022