

C/24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS; DELHI FIRE SERVICE, CONNAUGHT PLACE**

No. F6/DFS/MS/GH/2022/WZ/236

Dated: 20/05/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s. 19 West (Guest House) Located at Property No. RR-19, Mianwali Nagar, Paschim Vihar, Delhi-110087 is running at 1st, 2nd & 3rd Floors only in a building comprised of Basement + Ground + 03 Upper Floors owned/occupied by M/s. 19 West (Guest House) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 30.04.2022 in the presence of Sh. Ved Parkash Goyal, (Owner) and that the building/Premises is fit for occupancy "Residential Building" Group A of Sub Division – A-1 having 28 guest rooms (1st floor – 09 rooms, 2nd floor – 10 rooms & 3rd floor – 09 rooms) with effect from 20/05/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 20/05/2022 at New Delhi by


(In Charge)
Director
Delhi Fire Service

20/5/22

Copy to:-

1. The Addl. Commissioner of Police, Licensing unit, 1st Floor, Police Station, Defence Colony, New Delhi.
2. The Dy. Health Officer, West Zone, South Delhi Municipal Corporation, Rajouri Garden, New Delhi..
3. Sh. Ved Parkash Goyal, M/s. 19 West (Guest House) Located at Property No. RR-19, Mianwali Nagar, Paschim Vihar, Delhi-110087.

CONDITIONS

1. **This NOC is valid for 1st, 2nd & 3rd Floors only.**
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

N/3

1. Name & address of the building: **M/s. 19 West (Guest House)** Located at **Property No. RR-19, Mianwali Nagar, Paschim Vihar, Delhi-110087**
2. Type of Occupancy : Residential (1st, 2nd, & 3rd Floors)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : NBC 2005
6. Date of inspection : 27.04.2022
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sh. Ved Parkash Goyal (Owner)
9. Year of Construction/years of conversion : 2003/2015
10. Applicant's online application no. : 2022033004503 dated 01.04.2022
The above mentioned Guest House is running at 1st, 2nd, & 3rd Floors of a building comprised of Basement, Ground floor + 03 Upper Floors.

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	18 m	Provided	MR
	• Gate width	4.5 m	Direct accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	NA	closed	NA
	b. Width of staircases			
	• Upper floors	1.5 m & 1.25 m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	08 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

N/A

6.	First - Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Carbon Monoxide	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➢ Head of main pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby Pump out put	NA	NA	NA
	➢ Standby Pump Head	NA	NA	NA
	➢ Auto Staring/Manual stopping	NA	NA	NA
	➢ Pump House Access	NA	NA	NA
	• Terrace level			
	➢ Discharge of pump	450 lpm	Provided	MR
	➢ Head of the pump	40 mtrs.	Provided	MR
	➢ Power supply	Required	Provided	MR
	➢ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➢ Draw off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10.000ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➢ Pressurization of Lift Shaft	NA	NA	NA
	➢ Pressurization of lift lobby	NA	NA	NA
	➢ Communication in lift Car	Required	Provided	MR
	➢ Fireman's Grounding switch	Required	Provided	MR
	➢ Lift Signage	Required	Provided	MR


N/S

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC type Fire ext. provided near electrical panel	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcomings vide letter no. F6/DFS/MS/GH/2022/WZ/168 dated 24.02.2022 found rectified.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rules, grant of Fire Safety Certificate is recommended under rule 35 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

Accordingly DFA is prepared & put up for approval please.


 Aman Kumar Lathar
 ADO (JWZ)

DO(W)

The owner/occupier of M/s 19, West Guest-house applied for issuance of Fire Safety Certificate on MHA portal vide application ID 2021112327032.

He has submitted the sanctioned letter dated of plot No. RR-19, Meerowali Nagar, Paschim Vihar, New Delhi issued by DDA vide letter dated 19/02/2008 & Conversion Charges receipt dated 07/04/2015, 03/03/2016, 26/02/2016 & 25/10/2016.

D.O. (MIS) 291
DATED: 12/5/2022


As per inspection report, the requirement of corridor is mentioned as 1.5mt, whereas as per UBSL-2016, the requirement of double loaded corridor is 1.80mt.

If the width of Corridor of 1.5mt is accepted as per the document submitted by the management, the FSC for issuance is recommended.

A


Submitted please.

DO(WZ)


 12/05/2022

Director
11/05/2022

DO/WZ


 18/5/2022

A.D.O. (M/S) P.F.O.