

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2022/WZ/ School/510

Dated: 12/05/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **B. R. Tyagi Sr. Sec. School, Budh Vihar, Phase-II, Sector-24, Rohini, Delhi-86**, comprised of **Ground + 03 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2018/2765 dated 31.12.2018**. The premises was re-inspected by the officer concerned of this department on **28.04.2022** in the presence of **Miss. Maya Tyagi (Principal)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "**Group B' Educational** with effect from 12/05/2022 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/05/2022 at New Delhi by

  
**(Dhrampal Bhardwaj)**  
**Dy. Chief Fire Officer**  
**Tel:-01123414250**

Copy to :-

1. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054
2. The Principal, B. R. Tyagi Sr. Sec. School, Budh Vihar, Phase-II, Sector-24, Rohini, Delhi-86.

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year in Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

**INSPECTION REPORT**

1. Name & address of the building : B. R. Tyagi Sr. Sec. School, Budh Vihar, Phase-II, Sector-24, Rohini, Delhi-86.
2. Type of Occupancy : Educational (**Ground + 03 upper floors only**)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2018/2765 dated 31.12.2018
5. Fire Safety directives letter No : Director of Education dated 01.03.2005
6. Date of inspection : 28.04.2022
7. Name of the Inspecting Officers : A. K. Sharma ADO (Rohini)
8. Name and designation of officers from the building side : Miss. Maya Tyagi (Principal)
9. Year of Construction : **2004 ( As per NDMC Letter date 06.09.2018)**
10. Applicant's letter No. : OD No.7435 dated 21.03.2022.

	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>Circular of Director of Education</b>	<b>Provided at site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to building</b>			
	• Road width	Accessible	Provided	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.35m & 1.33m	MR(Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
e. Width of Corridor	NA	NA	NA	
f. Door Size	1 m	1.00 m	MR	
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	09nos	12nos	MR
	• Types	ABC/CO2	ABC—12	MR
	• ISI marking	ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			

N-9

	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level               <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450lpm	MR
		40m	40 m	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltrs	10,000 ltrs	MR
		Required	Provided	MR
15	<b>Exit Signage.</b>			
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A




2/10

19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.


Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in **Director of Education Circular**, and removal of shortcomings issued vide letter no. 674 dated 22.12.2021, the FSC issued vide letter no. F.6/DFS/MS/2018/2765 dated 31.12.2018, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.



Signature of the Inspecting Officer  
 Name **Ajay Kumar Sharma**  
 Designation **ADO(Rohini)**

DO (NW)


  
 09/05/2022  
 Dy. CRO (W2)

  
 10/5/2022

~~ADO Rohini~~  
 ms/ cell

FT letter is per up for- send / manual and  
 signature pls.

  
 DEPO

  
 11/5/2022



ms/ cell