



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS/ 2022/WZ/ 227

Dated: 20/05/2022

**FIRE SAFETY CERTIFICATE**

Certified that **Bharatiyam Village Foods and Beverages Pvt. Ltd.** located at **Village Bakoli, Palla Bakhtawarpur Road, Delhi-110036** comprised of Basement, Ground & Two upper floors owned/occupied by **Bharatiyam Village Foods and Beverages Pvt. Ltd.** was issued fire safety certificate vide **Letter No.F6/DFS/MS/2018/1279 dated 31/05/2018** have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 13/05/2022 in the presence of **Sh. Manoj Sharma** and found that the building premise is fit for occupancy under **“Class Sub Div. D-5 Assembly Building”** with effect from ...20/05/2022... for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on ...20/05/2022... at New Delhi by

(Dharampal Bhardwaj)  
Dy.Chief Fire Officer  
WEST ZONE

ou R

**Conditions for the validity of Fire Safety Certificate:**

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry”.
8. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Copy to:-

1. The Addl. Commissioner, North Delhi Municipal Corporation, Narela Zone, Delhi.
2. M/s Bharatiyam Village Foods and Beverages Pvt. Ltd, Village Bakoli, Palla Bakhtawarpur Road, Delhi-110036.

**INSPECTION REPORT**

1. Name & address of the building : M/s Bharatiyam Village Foods and Beverages Pvt. Ltd., Village Bakoli  
Palla Bakhtawarpur Road, Delhi-36
2. Type of Occupancy : Assembly
3. Building Comprised : Basement, Ground & Two upper Floors.
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2018/1279 Dated 31.05.2018
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 13.05.2022
8. Name of Inspecting Officer : ADO R.K Sinha
9. Name and designation of officers  
From the building side : Sh. Manoj Sharma
10. Year of Construction : 2012-13
11. Applicant's letter No. : E Mail id Dated 10.05.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	6 m 4.5 m NA	Provided 4.5 m NA	MR MR NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	01 01	02 02	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.20 m 1.20 m	1.20 m & 1.10 m 1.20 m & 1.10 m	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	Provided	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA NA NA NA	NA NA NA NA	NA NA NA NA
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	Exhaust Fan Natural Ventilation	MR MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	14 nos ABC & Co2 Yes	18 Provided Yes	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	01 30 m 5 mm	Provided 30 m 5 mm	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>			

R

	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150 mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	02	Provided	MR
		02	Provided	MR
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> <li>Pump house Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul> </li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		15,000 ltrs	15,000 ltrs	MR
		Required	Provided	MR
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

		Required	Provided	MR
17.	Standby power supply			
18.	Refuge Area.			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> <li>• Battery backup</li> </ul>	NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection system provided in the building were tested/checked and found functional at the time of inspection. Management has complied the shortcoming issued vide letter no. F6/DFS/MS/2022/WZ/FH/885 dated 22/04/2022.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended for renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/2018/1279 dated 31/05/2018, under rule 35 of the Delhi Fire Service Rules 2010.

Do (pow) on leave

Dy. FSO (02)

*(Signature)*  
ADO (BW)  
17/5/22

Signature of the Inspecting officer  
Name : Rajeev Kumar Sinha  
Designation : ADO/BW

*(Signature)*  
20/5/22

ADO

F T letter is pure for compliance

Dy. FSO (04)

*(Signature)*  
AD (BW)  
20/5/22

*(Signature)*  
20/5/22