

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No. F6/DFS/MS/2022/ 235

Dated: 26/05/2022

**FIRE SAFETY CERTIFICATE**

Certified that the building of Divya Prastha Hospital Located at RZ-37, Raj Nagar-1, Palam colony main road New Delhi comprised of Ground + 3 Upper Floors owned / occupied by **Divya Prastha Hospital** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the team of officers concerned of this department on 18-05-2022 in the presence of Sh. Madhav (Hospital Employee) and found that the said building is fit for occupancy class " **Institutional**" **Group C** with effect from 26/5/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/05/2022 at New Delhi by.

  
Atul Garg  
Director  
Delhi Fire Service

Copy to:

1. Dr. Gyan Vatsa (Medical Director) Divya Prastha Hospital Located at RZ-37, Raj Nagar-1, Palam colony main road New Delhi.
2. The MS, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, S-1, 3<sup>rd</sup> floor School Block, Shakarpur Delhi-110092.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expired.

7/2

**INSPECTION REPORT**

1. Name & address of the building: Divya Prastha Hospital Located at RZ-37, Raj Nagar-1, Palam colony main road New Delhi.
2. Type of Occupancy : Institutional (Hospital) comprised of Ground + 03 Upper floor
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : F6/DFS/MS /BP/2021/hospital/221 Dated 28/01/2021
6. Date of inspection : 18-05-2022
7. Name of the Inspecting Officer : DO / SW & ADO (DWK)
8. Name and designation of Officer :  
from the building side : Sh. Madhav (Hospital Employee)
9. Year of Construction : Old Structure
10. Applicant's letter No. : Email dated 09/05/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 m	Provided	MR
	• Gate width	5 m	provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	02 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2mtr & 1.5m	2 mtr & 1.5m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	2.40mts	Provided	MR
	f. Door Size	2.4 mts & 1.25 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

81N

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	10 nos.	Provided	MR
	• Types	ABC & CO2,	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided Strategic location	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	Required	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	1620 lpm	Provided	MR
	➤ Head of main pump	50 mtr	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	50 mtr	Provided	MR
	➤ Standby Pump out put	1620 lpm	Provided	MR
	➤ Standby Pump Head	50 mtr	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA



9/11

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	75,000 litre	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Accessible	Provided	MR
	• Overhead Tank capacity	10,000 Litres	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

**Note; - The Pumps are installed in adjoining shop owned by the hospital.**

Signature of the Inspecting Officer  
 Name *Dr. Veda*  
 Designation *DO*

*AB*  
*15/12/22*  
 Signature of the Inspecting Officer  
 Name *Uday Vir Singh*  
 Designation *ABO*

*Dy CPO (SZ)*  
*20/5*

C.F.O. 1. I don't agree with above note in re Pumps.  
 2. Agree this

*Dy CPO (SZ)*  
*ADD (Bhaskar)*  
*23/5/2022*  
*DO*  
*24/5/22*