

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/Petrol/2022/SZ/230

Dated: 23/05/2022

**FIRE SAFETY CERTIFICATE**

Certified that **M/s Gymkhana Service Station** Retail outlet Cum Service Station (Petrol, Diesel & CNG pump) at Race Course Club Road, New Delhi- 110003 comprised of Ground plus one upper floors only owned/occupied by M/s Gymkhana Service Station was issued FSC by this department vide letter No. F6/DFS/MS/2019/SZ/Petrol/1081 Dated 21/05/2019. The premises was re-inspected by the officer concerned of this department on 07/05/2022 in the presence of Mr. Gurvinder Singh Suri of the said filling station and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group-J, Hazardous Building** with effect from 23/05/2022 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 23/05/2022 at New Delhi by

(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (SZ)



Copy to: -

1. The Administrative Officer, South Zone, South MCD, Green Park, New Delhi-110016
2. M/s Gymkhana Service Station Retail outlet Cum Service Station (Petrol, Diesel & CNG pump) at Race Course Club Road, New Delhi- 110003

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any deviation, with regard to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

N/22

## INSPECTION REPORT

|    |   |  |
|----|---|--|
| 1  | Name & Address of the Building                        | M/s Gymkhana Service Station Retail outlet (Petrol Diesel) & CNG at Race Course Club Road, New Delhi |
| 2  | Type of Occupancy                                     | Hazardous Building (Group-J)   |
| 3  | Building Comprised of                                 | Ground plus one upper floor  |
| 4  | Type of Case  | Renewal  |
| 5  | Details of Previous NOC                               | F6/DFS/MS/2019/SZ/Petrol/1081 Dated 21/05/2019   |
| 6  | Fire Safety Directives Letter No                      | Nil  |
| 7  | Date of Inspection                                    | 07-05-2022   |
| 8  | Name of the Inspecting Officers                       | Sh. Rajesh Kumar ADO (BCP)   |
| 9  | Name & Designation of Officers from the building side | Mr. Gurvinder Singh Suri   |
| 10 | Year of construction                                  | 1998   |
| 11 | Applicant letter No.                                  | Gmail of Dated 08-04-2022  |

| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33   | Old NOC requirements                 | Provided at Site  | Remarks MR/NMR                       |
|-------|---|--------------------------------------|---|--------------------------------------|
| 1     | <b>Access to Building.</b>  |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>  | 09 mtr<br>-NA-<br>-NA-               | 12 mtr<br>-NA-<br>-NA-                                    | MR<br>-NA-<br>-NA-                   |
| 2     | <b>Number, width, type and arrangements of exits.</b>   |                                      |   |                                      |
|       | <b>a. Number of Staircase</b>   |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>  | 01 No<br>-NA-                        | 01 No<br>-NA-   | MR<br>-NA-                           |
|       | <b>b. Width of Staircase</b>  |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>  | 90 cm<br>-NA-                        | 90 cm<br>-NA-   | MR<br>-NA-                           |
|       | <b>c. Protection of exits</b>   |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>   | -NA-<br>-NA-                         | -NA-<br>-NA-  | -NA-<br>-NA-                         |
|       | <b>d. No. of continuous staircase to terrace</b>  | -NA-                                 | -NA-  | -NA-                                 |
|       | <b>e. Width of corridor</b>   | -NA-                                 | -NA-  | -NA-                                 |
|       | <b>f. Door size</b>   | 1 m                                  | Provided  | MR                                   |
| 3     | <b>Compartmentation.</b>  |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul> | -NA-<br>-NA-<br>-NA-<br>-NA-<br>-NA- | -NA-<br>-NA-<br>-NA-<br>-NA-<br>-NA-                      | -NA-<br>-NA-<br>-NA-<br>-NA-<br>-NA- |
| 4     | <b>Smoke Management system.</b>   |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>  | -NA-<br>-NA-                         | -NA-<br>-NA-  | -NA-<br>-NA-                         |
| 5     | <b>Fire Extinguishers.</b>  |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>   | 20 Nos<br>ABC/CO2/DCP<br>Required    | 25 Nos<br>CO <sub>2</sub> (4.5 kg) ABC & Foam<br>Provided | MR<br>MR<br>MR                       |
| 6     | <b>First Aid Hose Reels.</b>  |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>  | -NA-<br>-NA-<br>-NA-                 | -NA-<br>-NA-<br>-NA-                                      | -NA-<br>-NA-<br>-NA-                 |



N/24

|     |   |      |   |      |
|-----|---|------|---|------|
| 19. | <b>Fire Control Room.</b>   |      |   |      |
|     | • Detector System Panel.  | -NA- | -NA-  | -NA- |
|     | • Flow Switch Panel.  | -NA- | -NA-  | -NA- |
|     | • PA system Panel.  | NA   | NA  | NA   |
|     | • Battery backup  | -NA- | -NA-  | -NA- |
|     | • Building floor plan   | -NA- | -NA-  | -NA- |
| 20. | <b>Special Fire Protection System for the Protection of special Risk, if any.</b> | NA   | Co2 Flooding system provided in compressor, connected through gas detectors | MR   |

The fire protection system such as fire extinguisher of different type and capacity, Fire buckets filled with loose dry sand & water provided at suitable places in the retail outlet area were checked and found functional at the time of inspection. "No Smoking" sign board were found displayed both Hindi & English at conspicuous places. No loose electrical wiring was seen in the premises.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under rules, renewal of the FSC issued vide letter No. F6/DFS/MS/2019/SZ/Petrol/1081 Dated 21/05/2019, under rules 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*[Handwritten Signature]*  
13/05/2022

Signature of the inspecting Officer  
Name: Sh. Rajesh Kumar  
Designation: ADO(BCP)

DO (SD)

*[Handwritten Signature]*  
13/05/22

*[Handwritten Signature]*  
DFA (SD) F.T.

*[Handwritten Signature]*

ADO (BCP)

As approved, F.T. letter is put up for your signature pl

10/5  
18/5

*[Handwritten Signature]*  
DFA (SD)

M.S. *[Handwritten Signature]*