

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/NDZ/2022/ 225

Dated: 19/05/2020

FIRE SAFETY CERTIFICATE

Certified that the Old Boys hostel located at GTB Hospital Shahdara, Delhi -110095 comprised of Ground and 08 upper floors owned / occupied by GTB Hospital, was earlier issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2014/NDZ/1536 dated 09/12/14. The premises was re-inspected by the officers concerned of this department on 28.04.2022 in the presence of Sh. A.K. Singh, A.E.(E) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for occupancy class "**Residential Building**" (Group - 'A') with effect from 19/05/2022 for a period of five years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 19/05/2022 **at New Delhi by.**


(ATUL GARG)
DIRECTOR.

Copy to :-

1. The Medical Superintendent, GTB Hospital, Shahdara, Delhi-110095.
2. The Assistant Engineer (E), HE-1, HMED (East), PWD, GTB Hospital, Shahdara, Delhi-110095.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

N/1

1. Name & address of the building: Old Boys Hostel,GTB Hospital,Shahdara, Delhi-110095.
2. Type of Occupancy : Residential
3. Type of Case : Renewal (Ground, & Eight Upper Floors)
4. Details of previous NOC : F6/DFS/MS/2014/NDZ/1536 dated 09/12/2014
5. Fire Safety directives LetterNo. : DFS Prevention Act 1986 & 1987
6. Date of inspection : 28/04/2022
7. Name of the Inspecting Officer : ADO (TP) & D.O. (East)
8. Name and designation of Officer from the building side : Sh. A.K.Singh (AE(E))
9. Year of Construction : 1983

10. Applicant's letter No. : 54(1)AE(E) HE-I/HMED(East)/PWD/GTBH/2022-23/35 Dt.19/04/22

S No	Minimum standards on fire prevention and fire safety U/R 33	As per Delhi Fire Prevention & Fire Safety Act 1986&1987	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	26 m	MR
	• Gate width	4.5 m	6 m	MR
	• Width of internal road	6 m	6 m	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4	4	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.00 m	1.10 m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	4	4	MR
	e. Width Of Corridor	1.5 m	1.5 m	MR
	f. Door Size	1 m	1 m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	20	26	MR
	• Types	ABC/CO ₂	Provided	MR
	• ISI marking	Required	Provided	MR

6.	First Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	20 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Ground Floor	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements Common for entire complex			
	• Ground Level			
	➤ Discharge of main pump	2850 LPM	2850 LPM	MR
	➤ Head of main pump	70 m	70 m	MR
	➤ Number of main pumps	02 nos.	02 nos.	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	70 m	70 m	MR
	➤ Standby Pump out put	2850 LPM	2850 LPM	MR
	➤ Standby Pump Head	70 m	70 m	MR
	➤ Auto Starting/Manual stopping	Auto	Auto	MR
	➤ Pump House Access	Required	Required	MR
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	2,00,000 Ltrs.	2,00,000 Ltrs.	MR
	➤ Draw of connection	Required	Required	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Required	MR
	• Overhead Tank capacity	N/A	N/A	N/A

K. D.

N/3

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Mehmood
Signature of the Inspecting Officer
Name : Mehmood
Designation : A.D.O. (Tahirpur)

Ashok Kumar Jaiswal
Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East Division)

DY CEO/(NDZ)

Mehmood
10/5/22
cfo
11/5/22

Sl. No 14 is common for entire complex
This should be confirmed.

Mehmood
13/5/22
Director



Mehmood
13/5/22
DY CEO Captive water storage for fire fighting is common for entire complex i.e. (G.T.B. Hospital Complex.). F.T. is put up for sign. please.

DY. CEO/(NDZ)
Mehmood
13/5/22
Director

Ashok Kumar Jaiswal
17/05/22