

G 80

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/School/SZ/2022/562

Dated: 20/05/2022

FIRE SAFETY CERTIFICATE

Certified that **Sarvodaya Kanya Vidyalaya, F-Block, Budh Nagar, Inderpuri, New Delhi - 110012**, comprised of ground plus three upper floors (newly constructed block) was inspected by the officer concerned of Delhi Fire Service on 09.05.2022 in the presence of Sh. Ikramul (Supervisor), and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with Delhi Fire Service Act 2007 and Rules 2010 and that the building/premises is fit for occupancy class "Educational" with effect from 20/05/2022 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below

Issued on 20/05/2022 at New Delhi by.


(Signature)
Director

Delhi Fire Service

Copy to: -

1. The Principal, Sarvodaya Kanya Vidyalaya, F-Block, Budh Nagar, Inderpuri, New Delhi - 110012.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
3. The Assistant Engineer (E), Sub-Div- 1 Education Division M 1 (N), PWD GINCE, Govt. of Delhi, ITI Campus, Pusa Road, New Delhi- 110012.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, F-Block, Budh Nagar, Inderpuri, New Delhi - 110012
2. Type of Occupancy : Educational
3. Building Composition : Building comprised ground plus three upper floors.
4. Type of Case : New Case
5. Details of previous NOC : N/A
6. Fire Safety directives letter No : N/A
7. Date of inspection : 09.05.2022
8. Name of the Inspecting Officers : P.V. Rathee, Asstt. Div. Officer (SRD)
9. Name and designation of officers from the building side : Sh. Ikramul (Supervisor)
9. Year of Construction : 2020
10. Applicant's letter No. : 54(SPS School)/PWD Edu.Sub-Divn M1-1(N)/2022-23/Camp(01) dated 25.04.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Directly assessable	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02	02	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.50 mts each	1.68 & 1.80 mts	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02	02 Nos.	MR
	g. Width of Corridor	1.5 mts	1.80 mts	MR
	h. Door Size	1.20 mts	1.20 mts at each class room	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural Ventilation	MR

16	Provision of Lifts.	Not Applicable		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked at random and found satisfactory at the time of inspection.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the Rules, it is recommended to grant fire safety certificate under Delhi Fire Service Act-2007 & Rules- 2010.

Accordingly, DFA is put up for approval & signature please.

D.O. (SW) *AB* 11/5/22
 Dy. Insp. (S2) *[Signature]* 12/5/22
 C.F.O. *[Signature]* 12/5/2022
 Director *[Signature]* 12/5/22
 104 SRD

[Signature] 10/5/22
 Signature of the Inspecting Officer
 (P.V. Rathee)
 Asstt. Div. Officer, (SRD)