

49

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No.F 6 DFS/MS/School/2022/SZ/ 571

Dated 27/05/2022

FIRE SAFETY CERTIFICATE

Certified that **Vidya Niketan Public School located at Nanak Pura, Moti Bagh, New Delhi 110021** comprised of Basement, (Storage only) ground plus two upper floors owned/occupied by Vidya Niketan Public School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/SZ/2019/1370 Dated 02/07/2022. The said premise was re-inspected by officer concerned of this department on 14/05/2022 in presence of Mr. Suresh Sharma (Chairman) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 27/05/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 27/05/2022 at New Delhi by


(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to :-

1. The Principal, Vidya Niketan Public School located at Nanak Pura, Moti Bagh, New Delhi 110021
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/G

INSPECTION REPORT

1	Name & Address of the Building	Vidya Niketan Public School, Nanak Pura, Moti Bagh, New Delhi-110021 (ID: 1719118)		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Basement, Ground + 02 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/SZ/2019/1370 Dated 02/07/2022		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01 03 2011		
7	Date of Inspection	14/05/2022		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Suresh Sharma (Chairman)		
10	Year of construction	1996		
11	Applicant letter No.	Gmail of dated 13-04-2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Assessable	9 mtr	MR
	• Gate width	-NA-	5 mtr	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	01 No	02 Nos	MR
	➤ Basement floor.	02 Nos	02 Nos	MR
	b) Width of Staircase			
	➤ Upper floors	1.5m or less & 0.75m	1.50m & 1.20m	MR
	➤ Basement floor	1.5m or less & 0.75m	1.50m & 1.20m	MR
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	One	Provided	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1m	1.2m	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5	Fire Extinguishers.			
	• Total numbers	10 Nos	16 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A

Vidya Niketan Public School at Nanak Pura, Moti Bagh, New Delhi-110021

8	MOEFA	N/A	N/A	N/A
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper floors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	N/A	100 mm	N/A
	<ul style="list-style-type: none"> Number of Hydrant per floor 	N/A	One	N/A
	<ul style="list-style-type: none"> Hose box. 	N/A	One	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose box. 	N/A	N/A	N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump house access. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	900 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of pump. 	40m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	N/A	25,000 Lts	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead tank capacity. 	15,000 Ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication in lift car. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's switch. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift signage. 	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Flow switch panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> PA system panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Battery backup. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Building floor plan. 	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	Sand buckets with stand filled with loose sand & ABC fire extinguisher provided near electrical panel		MR

N/8

Vidya Niketan Public School at Nanak Pura, Moti Bagh, New Delhi-110021

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/SZ/2019/1370 Dated 02/07/2022, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

18/6
13/5/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

~~DO (SD)~~

~~ADP~~
~~13/5/22~~

F.T.

~~DCFO(S/2)~~



~~ADO (BCP)~~

As approved, F.T. letter is put up for your signature Pl.

18/6
13/5/2022

~~DCFO(S/2)~~



M.S. all