

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/Bnqt/2022/NDZ/241

Dated: 30/05/2022

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Bliss and Blessing banquet located at Ground floor at PD area of Jhilmil Metro Station, Delhi-110095, owned/occupied by M/s GRT Fusion Pvt. Ltd. have complied with fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules,2010,and verified by the officer concerned of Fire Service on 25/05/2022 in presence of Sh. Gaurav Kapoor (Partner) and that the buildings/premises is fit for occupancy class "Assembly (Group-D)-Banquet Hall" with effect from 30/05/2022 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....30/05/2022.....at New Delhi by

  
(Atul Garg)  
Director  
%c 8

Copy to,

1). Sh.Gaurav Kapoor  
Bliss & Blessing banquet GF  
PD Area at Jhilmil Metro Station,  
Delhi-110032

MHA Id:- 2022022602731 date-27/02/22

2). The Dy. Health Officer  
EDMC, Public Health Department  
Shahdara (South) Zone, Karkardooma, Shahdara, Delhi-110032

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/A 3

1. Name & address of the building: Bliss and Blessings Banquet, G.F.  
PD Area at Jhilmil Metro Station, Delhi-110095.
2. Building is comprised of : Ground+ One upper floor  
(Banquet is running on groundfloor)
3. Type of Occupancy : Assembly Building
4. Type of Case : New
5. Details of Previous FSC letter : Nil
6. Fire safety directive letter no. : F.6/DFS/MS/2020/2626 Dt. 28/10/2020
7. Date of Inspection : 25/05/2022
8. Name of the Inspecting officer : ADO (T.P)
9. Name and designation of  
Officer from the building side : Mr. Gaurav Kapoor (Owner)
10. Year of Construction : 2019
11. Applicant's letter No : 2022022602731 dated 27/02/2022

S N	Minimum Standards on fire prevention and fire safety U/R33	Directive Cir. Requirement	Provided at Site	Remark
1	Access to building			
	• Road width	30 M	30 M	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2.0mtr	2.0mtr each	MR
	g. No. of Doors	05 nos	05nos	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	02 hrs	02 hrs	MR
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	10 Nos.	10 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR



11/14

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 Nos	01 Nos	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Heat & Smoke	Provided	MR
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	Ground Floor	Provided	MR
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooter's location	Different Location	Different Location	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	Provided	MR
	• sprinkler above false ceiling	N/A	Provided	MR
11	Internal Hydrants			
	• size of riser/down-comer	150mm	150mm	MR
	• Number of hydrants per floor	02 Nos.	02 no.	MR
	• Hose Box	02 Nos.	02 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	<b>Provided for entire Metro Building</b>		
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	2850Lpm	2850Lpm	MR
	➤ Head of Main Pump	70 M	70 M	MR
	➤ Number of main pumps	02 Nos.	02 Nos.	MR
	➤ Jockey pump out put	180 Lpm x 2	180 Lpm x 2	MR
	➤ Jockey pump head	70M	70M	MR
	➤ Standby pump out put	2850 Lpm	2850 Lpm	MR
	➤ Standby pump Head	70 M	70 M	MR
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	<b>Provided for entire Metro Building</b>		
	• Underground tank capacity	2,00,000 Ltrs	2,00,000 Ltrs	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	N/A	20,000 ltrs.	N/A
15	Exit Signage.	Required	Provided	MR

N/15

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Note:- Over head Tank having capacity 25,000 ltrs. is not required for P.D area at metro station as per annexure J-9.1.9.(NBC Part-IV 2016) as done in Shree Shyam palace banquet hall, Mansarovar Park PD area. The width of door 2.0 mtr is only required.

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules F.6/DFS/MS/2020/2626 Dt. 28/10/2020, it is recommended to issue Fire Safety Certificate under the 35 of Delhi fire Service rules 2010.

*Mehmood*  
27/05/22

Signature of the Inspecting Officer

Name : Mehmood

Designation : A.D.O. (T.P)

~~D.O.(ED)~~

Sir,

As per J-9.1.9 (NBC - Part - IV 2016) over tank in Metro P.D. Area is not required as there is already UGSST of capacity 2,00,000 (2 lac) ltrs is provided.

Before sending file to competent Authority, it should be vetted through FPW.

Submitted pl.

Dy. CFO (ND2)

*Mehmood*  
27/05/22

D.O.(FPW)/East

*Mehmood*  
27/05/22