

G-73

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/EH/2022 / W2/133

Dated 20/05/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Cafeteria and Co. (A Unit of Jumbo Restaurant Pvt. Ltd) located at G-14, 1st Floor, 2nd Floor & 3rd Floor, Vijay Nagar, Delhi comprised of ground and 03 upper Floors owned/ occupied by M/s Cafeteria and Co. (A Unit of Jumbo Restaurant Pvt. Ltd) was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/2019/1737 dated 06.09.2019 The premises was re-inspected by the officers concerned of this department on 04.05.2022 in the presence of Sh. Sandeep Yadav (Manager) and found the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and building/ premise is fit for occupancy Class- "D" (Assembly) occupancy with effect from 20/05/2022 for a period of 03 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/05/2022 at New Delhi by

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph. No. 011-23414250

Copy to:-

1. The Joint Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate. six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s Cafeteria and Co. (A Unit of Jumbo Restaurant Pvt. Ltd.),G-14, 1st Floor, 2nd Floor & 3rd Floor, Vijay Nagar, Delhi.
2. Composition of building : Ground + 03 upper floors. Ground---Shops (Other property) and (Restaurant running on 1st, 2nd & 3rd floor Kitchen only)
3. Type of Occupancy : Mixed Occupancy (Assembly/ Mercantile)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFPS/MS/2019/1737 Dated: 06.09.2019
6. Fire Safety directives letter No : NBC Part IV
7. Date of inspection : 04.05.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Mr. Sandeep Yadav (Manager)
10. Year of Construction : ----
11. Applicant's letter No. : Online MHA Portal No.2022041206758 dated 14.04.2022.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	12m (approx)	MR
	• Gate width	4.5m	Directly accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50 m	1.50m & 1.25m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2.0m	1.50m & 1.25m	MR
3	Compartmentation.			
	• Fire check door	Required to segregate Kitchen & Staircase	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			

N/19

	<ul style="list-style-type: none"> Basements Upper floors 	12 a/c per hour	NA	MR
		12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	08nos	15nos	MR
		ABC/Co2	15 ABC	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	01	MR
		30 m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided all level	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	Provided	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump 	1620lpm	1620lpm	MR
		60m	60m	MR
		01	01	MR
		180lpm	180lpm	MR
		60m	60m	MR
		1620lpm	1620lpm	MR
		60m	60m	MR
		Required	Provided	MR
		450lpm	450lpm	MR
		40m	Provided	MR

Signature

	➤ Head of the pump	Required	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump			
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	50,000 ltrs	50,000 ltr.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 ltr	5,000 ltrs	MR
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
		Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:			
		NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. 173773 dated 06.09.2019 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DO (RW)

09/05/2022

By (W2)

10/5/22

07/05/2022

Signature of the Inspecting Officer

Name: - C.L. Meena

Designation:- ADO/RN

ADO/RN

As approved fire letter is setup for your signature pl. —

12/5/2022

P.T-0