

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/EH/SZ/2022/140

Dated. 23/05/2022

FIRE SAFETY CERTIFICATE

Certified that M/s **McDonald's Family Restaurant** (A Unit of Connaught plaza Restaurant Pvt Ltd) located at **First Floor, E-31 & 32, South Extension Part-II, New Delhi 110049** in the building comprised of Basement, Ground plus three upper floor owned/occupied by M/s Connaught Plaza Restaurant Pvt. Ltd. was issued FSC by this department vide letter no. F6/DFS/MS/EH/SZ/2019/1395 dated 08/07/2019. The restaurant premise was re-inspected by the officer concerned of this department on 12/05/2022 in the presence of Sh. Puneet Sharma (Manager) of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** Restaurant as above with effect from 23/05/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/05/2022 at New Delhi by

(SUNIL CHAWDHARY)
 DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Dy. Health Officer, South MCD, Health Trade Department, South Zone Green Park, Aurobindo Marg, New Delhi 110016. (MHA Portal ID 2022041807337 dated 18-04-2022)
2. M/s McDonald's Family Restaurant (A Unit of Connaught plaza Restaurant Pvt Ltd) located at First Floor, E-31 & 32, South Extension Part-II, New Delhi 110049.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

N/18

INSPECTION REPORT

1	Name & Address of the Building	McDonald's Family Restaurant, at First Floor, E-31 & 32, South Extension Part-II, New Delhi		
2	Type of Occupancy	Assembly 'Group-D' (Restaurant running at first floor only)		
3	Building comprised of	Basement, Ground plus 03 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/SZ/2019/1395 dated 08/07/2019		
6	Fire Safety Directives Letter No	F6/DFS/MS/EH/2005/718 dated 04-04-2005 (N-1)		
7	Date of Inspection	12.05.2022		
8	Name of the Inspecting Officers	Rajesh Kumar/ ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Puneet Sharma		
10	Year of construction/ date of conversion	1996		
11	Applicant letter No.	MHA Portal ID 2022041807337 dated 18-04-2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per old NOC	Provided at Site	Remarks
1	Access to Building.			
	• Road width	Required	6 mtr	MR
	• Gate width	NA	NA	-NA-
	• Width of internal road	NA	NA	-NA-
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	02 Nos	03 Nos	MR
	• Basement floor	NA	Other property	-NA-
	b. Width of Staircase			
	• Upper floors	1.25 m/0.90 m	1.25 m, 1 m & 0.92m	MR
	• Basement floor	NA	NA	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	NA	-NA-
	• Pressurization	-NA-	NA	-NA-
	d. No. of continuous staircase to terrace	Required	01 Nos	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.50 m	1.50 m & 1.50 m	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	12 ACPH	Exhaust fan	MR
5	Fire Extinguishers.			
	• Total numbers	06 Nos	06 Provided	MR
	• Types	ABC / CO2	W co2, ABC & Co2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A

N/A

	<ul style="list-style-type: none"> Hooper's location 	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	-NA-	NA	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	NA	-NA-
		Required	Provided	MR
		N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main pump. ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output. ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting / Manual Stopping. ➤ Pump House Access 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		N/A	-NA-	-NA-
		N/A	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump. 	900 & 225 LPM	Provided	M/R
		40 m	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	M/R
		-NA-	-NA-	-NA-
		5,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector System Panel. 	-NA-	-NA-	-NA-

11/20

	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any :	-NA-	-NA-	-NA-

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/SZ/2019/1395 dated 08/07/2019 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Handwritten signature and date: 18/5/2022

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO / BCP

DO (SD)

Handwritten signature and date: 17/05/22

Handwritten signature: Delfo (13)

Handwritten initials: F.T.

Handwritten signature

Handwritten signature: (A D O B / P)

As apporoned, F.T. letter is put up for your signature pl.

Handwritten signature and date: 18/5/2022

Handwritten signature: Delfo/2

Handwritten signature: M.S. Ull

Handwritten text: uploaded by zeeshan