

460

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001
No.F6/DFS/MS/School/NDZ/2022/591 Dated:- 30/05/2022

FIRE SAFETY CERTIFICATE

Certified that the **Kerala Education Society Sr. Sec. School** located at **Pocket A-3, Mayur Vihar Phase-III, Delhi-96** comprised of **Ground + 03 Upper floors** owned/occupied by Kerala Education Society Sr. Sec. School has already been issued Fire Safety Certificate vide letter No. **F6/DFS/MS/School/2017/NDZ/300** dated **02/03/2017**. The premises was re-inspected by the officer concerned of this department on **23/05/2022** in the presence of the Mr. Latha Nandkumar (HOS) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the **Circular No. F.16/Estate/CC/FS/2011/3298-3398** dated **01/03/2011** and found that the building is fit for occupancy of class **Group B "Educational Building,"** as above **Ground + 03 upper floors only** with effect from 30/05/2022 renewed for a period of three years, subject to conditions printed below.

Issued on 30/05/2022 at New Delhi by.


27/5/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director of Education,
Government of N.C.T. Delhi,
Old Sectt. Delhi – 110054.
2. The Principal,
Kerala Education Society Sr. Sec. School,
Pocket A-3, Mayur Vihar Phase-III, Delhi-96.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

N/12

INSPECTION REPORT

1. Name & address of the building Kerala Education Society Sr. Sec. School,
Pocket A-3, Mayur Vihar-III, Delhi-96.
2. Type of occupancy:- Educational Group-B
Gr. + 03 upper floors
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/School/2017/NDZ/300 dated
02/03/2017
5. Fire safety directives No.- F.6/DFS/MS/BP/2002/1963 dated 16/10/02
6. Date of inspection:- 23/05/2022
7. Name of the inspecting officer:- Sh. A.K. Jaiswal (DO/ED) &
Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer
From the building side:- Mr. Latha Nandkumar (HOS)
9. Year of construction:- 2005 & 2015
10. Applicant's letter No:- email dated 12/04/2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	24 mtr.	MR
	2) Gate width	05 mtr.	05 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 no.	02 no.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 m	2.0 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 nos.	02 nos.	MR
	E. Width of corridor	1.5 mtr.	2.0 mtr.	MR
	F. Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	12 Nos.	15 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI marked	ISI marked	MR

x/1/18

6.	First-Aid Hose Reel			
	1) Total number of each floor	02 nos.	02 nos.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	Provided	MR
	2) Number of hydrants per floor	1 nos.	Provided	MR
	3) Hose box	1 nos.	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	2) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	3) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	40 mtr.	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10,000 ltr.	20,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR

22

2

2

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/CGHS/2003/2947 dated 02/12/2003 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Mush
23/05/22

A.K. Jaiswal
23/05/2022

Name :- M.K. Sharma
Designation :- ADO (LN)

Name :- A.K. Jaiswal
Designation :- DO (ED)



Dy. CTO (NB2)
K. G. Mittal
25/5/22

~~DO (ED)~~
A.K. Jaiswal
25/5/2022

ADDO K. N.

F.T. letter is put up for copy
Mush
26/5/22

Dy. CTO (NB2)
K. G. Mittal
27/5/22