

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No. F6/DFS/MS/WZ/Club/2022/ 240

Dated: 30/5/2022

FIRE SAFETY CERTIFICATE

Certified that the **M/s. Shalimar Bagh Club**, located at Plot No.- 09, B-Block, Shalimar Bagh, New Delhi-110088, in a building comprised of Basement, Ground plus two upper floors was issued vide letter No. F.6/DFS/MS/Club/2019/981 dated 10.05.2019, owned / occupied by **M/s. Shalimar Bagh Club**, was re-inspected by the officer concerned of this department on 26/05/2022 in the presence of Sh. T.R Garg & Sh. Dharmender Pradhan and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class **Assembly (Group – D)** with effect from 30/5/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions, under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 30/5/2022 at New Delhi.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

OIC BP

Copy to: -

1. Sh. Subhash Chander Lamba, M/s. Shalimar Bagh Club, Plot No.- 09, B-Block, Shalimar Bagh, New Delhi-110088.
2. The Joint Commissioner of Police, Licensing Unit, 1st Floor, Police Station Defence Colony, New Delhi.
3. The DHO, Keshav Puram Zone, North DMC, Kesav Puram, Wazirpur, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of unified building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. “The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry”.
8. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: M/s. Shalimar Bagh Club, Plot No.- 09, B-Block, Shalimar Bagh, New Delhi-110088.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/Club/2019/981 dated 10.05.2019
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2000/913 dated 25.05.2000
6. Date of inspection : 26.05.2022
7. Name of the Inspecting Officer : M.K. Chattopadhyay, DO (West)
8. Name and designation of Officer
From the building side : Sh. T.R Garg & Sh. Dharmender Pradhan
9. Year of Construction : 2005
10. Applicant's email date : Online MHA ID- 2022052311005

The said building is comprised of basement, ground plus two upper floors.

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per Rule 35 (6) of DFS Act- 2007	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mts	Provided	MR
		05 mts	02x 3.9 mts provided	MR being old case
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits:			
	➤ Number of staircases			
	a. Upper floors	02	Provided	MR
	b. Basements	02	Provided	MR
	➤ Width of staircases			
	c. Upper floors	Old Case	1x1.30, 1x0.98 mts	MR being old case
	d. Basements	Old Case	1x2.90, 1x0.98 mts	MR being old case
	e. Protection of exits			
	f. Fire check door	Required	Provided	MR
	g. Pressurization	NA	NA	NA
	h. No of continuous staircase to terrace	01	Provided	MR
	i. Width Of Corridor	NA	NA	NA
	j. Door Size	2.0 & 1.0 m	1.66 & 0.78 mts	MR being old case
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Iron gate provided in basement	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System:			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Provided	MR
		12 a/c per hour	Provided in kitchen	MR



5.	Fire Extinguishers			
	➤ Total numbers	18 nos.	Provided	MR
	➤ Types	ABC & CO ₂	Provided	MR
	➤ IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	➤ Total numbers on each floor	01	Provided	MR
	➤ Length of hose reel hose	30 m	Provided	MR
	➤ Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system:			
	➤ Type of detectors	Heat & smoke	Provided	MR
	➤ Location of Main Panel	Ground floor	Provided	MR
	➤ Location of Repeater Panel	Each floor	Provided	MR
	➤ Alternate source of power	Required	Provided	MR
	➤ Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System:			
	➤ Basements	Required	Provided	MR
	➤ Upper Floor	Required	Provided	MR
	➤ Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	➤ Size of riser/down- comer	150 mm	Provided	MR
	➤ Number of hydrants per floor	01	Provided	MR
	➤ Hose Box	01	Provided	MR
12.	Yard Hydrants			
	➤ Total number of hydrants	Required	Provided	MR
	➤ Hose Box	Required	Provided	MR
13.	Pumping Arrangements:			
	➤ Ground Level	1620 LPM	Provided	MR
	➤ Discharge of main Pump	40 mts	Provided	MR
	➤ Head of main pump	01	Provided	MR
	➤ Number of main pumps	250 LPM	Provided	MR
	➤ Jockey pump out put	40 mts	Provided	MR
	➤ Jockey pump head	1620 LPM	Provided	MR
	➤ Standby Pump out put	40 mts	Provided	MR
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	➤ Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for firefighting:			
	➤ Underground tank capacity	50,000 lts	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	➤ Overhead Tank capacity	12,500 lts	Provided	MR
15	Exit Signage	Required	Provided	MR

16.	Provision of Lifts (Running from Ground to Second Floor)			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/Club/2019/981 dated 10.05.2019, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

DFA is put up for approval & signature please.

D.O. (WEST)/.....
DATED.....

DCFO (WZ)

[Handwritten signature]
27/5/2022

[Handwritten signature]
26/5/2022

Signature of the Inspecting Officer
Name: M.K. Chattopadhyay
Designation: DO (West Division)

Put up F.T / ADD Bhyambur

AS approved F.T. letter is put up for signature pls.

DCFO (WZ)

[Handwritten signature]
30/5/2022

[Handwritten signature]
30/5/2022

[Handwritten signature]