

C-64

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

**NEW DELHI-110001**

No. F.6/DFS/MS/EH/2022/SZ/1142

Dated. 27/05/2022

**FIRE SAFETY CERTIFICATE**

Certified that **M/s Swagath Restaurants** located at **14 GF, 13 FF & 13 SF, Defence Colony, New Delhi 110024** in the building comprised of Basement, ground plus two Upper floors owned/occupied by Mr. Jayaram Banan was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2019/SZ/870 Dt. 22/04/2019. The restaurant premise was re-inspected by the officer concerned of this department on 23/05/2022 in the presence of Mr. Shridhar (Manager) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** (**Restaurant running at Ground plus two upper floor**) as above with effect from 27/05/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/05/2022 at New Delhi by



**(SUNIL CHAUDHARY)**  
**DY. CHIEF FIRE OFFICER (SZ)**

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi-16 (Ref. MHA Portal ID 2021092822708 dated 09/03/2022)
2. M/s Swagath Restaurants located at 14 GF, 13 FF & 13 SF, Defence Colony, New Delhi 110024

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

**INSPECTION REPORT**

1	Name & Address of the Building	M/s Swagath located at 14 GF, 13 FF & 13 SF, Defence Colony, New Delhi 110024.		
2	Type of Occupancy	Group-D-4 Assembly (Restaurant running at Ground +2 upper floors)		
3	Building Comprised of	Basement, Ground +Two upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2019/SZ/870 Dt. 22/04/2019		
6	Fire Safety Directives Letter No	Circular dated 04.04.2005		
7	Date of Inspection	23/05/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Shridhar (Manager)		
10	Year of construction	2002		
11	Applicant letter No.	MHA Portal ID 2021092822708 dated 09/03/2022		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC Requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
1	Access to Building.			
	Road width	6 mtr	10 mtr	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	Upper floors.	02 No's	02 Nos	MR
	Basement floor.	02 No's	02 Nos	MR
	b. Width of Staircase			
	Upper floors	1.25 mtr	1.20 & 0.70 mtr	MR (old case)
	c. Basement floor	1.25 mtr	1.20 & 0.70 mtr	MR (old case)
	d. Protection of exits			
	Fire check door	N/A	N/A	N/A
	e. Pressurization	N/A	N/A	N/A
	f. No. of continuous staircase to terrace	Required	01 Provided	MR
	g. Width of corridor	N/A	N/A	N/A
	h. Door size	2 Nos	1.2m & 0.90m	MR (old case)
3	Compartmentation.			
	Fire check door.	N/A	N/A	N/A
	Sealing of electrical shafts.	Required	Provided	MR
	Fire rating of shaft door.	N/A	N/A	N/A
	Water curtain	N/A	N/A	N/A
	Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	Basement	30 ACPH	Exhaust fan	MR
	Upper floors	12 ACPH	Exhaust fan	MR
5	Fire Extinguishers.			
	Total numbers	16 Nos	16 Nos	MR
	Types	ABC/CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	Total numbers on each floor.	One	Provided	MR
	Length of hose-reel hose.	30m	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	Type of detectors	N/A	N/A	N/A
	Location of Main Panel	N/A	N/A	N/A



	Location of Repeater Panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	Basement	Required	Provided	MR
	Restaurant area	Required	Provided	MR
	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.			
	Size of Riser/Down-comer	N/A	N/A	N/A
	Number of Hydrant per floor	N/A	N/A	N/A
	Hose box.	N/A	N/A	N/A
12	Yard Hydrants.			
	Total number of hydrants.	N/A	N/A	N/A
	Hose box.	N/A	N/A	N/A
13	Pumping arrangements.			
	Ground Level			
	Discharge of main pump.	N/A	N/A	N/A
	Head of main pump.	N/A	N/A	N/A
	Number of main pumps.	N/A	N/A	N/A
	Jockey Pump output.	N/A	N/A	N/A
	Jockey Pump head.	N/A	N/A	N/A
	Standby Pump output.	N/A	N/A	N/A
	Standby Pump head.	N/A	N/A	N/A
	Auto Starting/Manual Stopping.	N/A	N/A	N/A
	Pump house access.	N/A	N/A	N/A
	Terrace Level			
	Discharge of pump.	450 & 180 LPM	Provided	MR
	Head of pump.	35m	Provided	MR
	Power supply.	Required	Provided	MR
	Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	Underground tank capacity.	N/A	N/A	N/A
	Draw-off connection.	N/A	N/A	N/A
	Fire Service Inlet.	Required	Provided	MR
	Access to tank.	N/A	N/A	N/A
	Overhead tank capacity.	5,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of lift shaft.	N/A	N/A	N/A
	Pressurization of lift lobby.	N/A	N/A	N/A
	Communication in lift car.	N/A	N/A	N/A
	Fireman's switch.	N/A	N/A	N/A
	Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room.			
	Detector system panel.	N/A	N/A	N/A
	Flow switch panel.	N/A	N/A	N/A
	PA system panel.	N/A	N/A	N/A
	Battery backup.	N/A	N/A	N/A

N/21

	Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2019/SZ/870 Dt. 22/04/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Sh. Rajesh Kumar*  
24/5/2022

Signature of the Inspecting Officer  
Name: - Sh. Rajesh Kumar  
Designation: - ADO/BCP

~~DO (SD)~~

*Sh. Rajesh Kumar*  
24/05/22  
*DFA (SD)*  
*Sh.*

*ANA (SD)*

As approved, F.T. letter is put up for your signature pl

*Dy CFS/2*  
*Sh.*

*Sh. Rajesh Kumar*  
26/5/2022

*MS. OJ*