

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2022/ School/WZ/ 568

Dated: 26/05/2022

FIRE SAFETY CERTIFICATE

Certified that **White Leaf Public School** located at , **Main Narela Road, Bawana, Delhi-110039** comprised of **Two Blocks-Ground+one upper floor** owned/occupied by **White Leaf Public School** was issued fire safety certificate **vide letter no. F-6/DFS/MS/2021/School/WZ/347 Dated-22/04/2021**. The premises was re-inspected by the officer concerned of this department on 13.05.2022 in the presence of Smt. Anila Rani (Manager) and observed that the management has added two more floors in 01 block of existing building of 02 blocks and now building is comprised of **Two Blocks (01 Block-Ground+One upper floor) & (01 Block-Ground+three upper floors)**. All the fire prevention & fire safety arrangement provided in the building was found as per Rules and in good working condition. The premises have therefore complied with the requirements under rule 33 of Delhi Fire Service Rules, 2010 and the building / premises is fit for occupancy of **Group B (Educational)** with effect from 26/05/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules,2010.

Issued on 26/05/2022 at New Delhi


(Signature)
Director
Delhi Fire Service
OKR

Copy to : -

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.
2. The Principal , White Leaf Public School, Narela Road, Bawana, Delhi-110039.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : White Leaf Public School, Narela Road ,Bawana , Delhi-110039.
2. Type of Occupancy : Educational
3. Building Comprised : Previous-Two Blocks(Ground + One upper floor), Now- Two Blocks (01-Ground +First floor) and(01-Ground +three upper floors)
4. Type of Case : New (Addition of floors)
5. Details of Previous NOC : Letter No. F.6/DPS/MS/2017/School/WZ/635 Dated-04/05/2017
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 13/05/2022
8. Name of Inspecting Officer : ADO (BW)
9. Name and designation of officers
From the building side : Smt. Anila Rani (Manager)
10. Year of Construction : 1999, 2010 & 2021
11. Applicant's letter No. : Nil , Dated-21/04/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floor	1.50 m	1.80 m & 1.60 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	1.80 m	2.30 m	MR
	f. Door Size	1.20 m	1.20 m double door	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA

h

	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	18	25	MR
	<ul style="list-style-type: none"> Types 	ABC	ABC	MR
	<ul style="list-style-type: none"> IS marking 	Yes	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	02	02	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	30 m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Ground Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	NA	NA	NA
		NA	NA	NA

	➤ Pump House Access	NA	NA	NA
	• Terrace level	-	-	-
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	-	-	-
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

P2

--	--	--	--	--

The Fire Safety Certificate was issued for a building comprised of 02 Blocks (Gr.+One upper floor), now management has added two more floors in existing one block of building and now the building is comprised of 02 Blocks (01Block-Gr+one upper floor) & (01 Block-Ground+Three upper floors). The fire protection systems provided in the building were as per Rules & tested, checked and found functional at the time of inspection.

Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended for Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

~~Do (w)~~

~~19/05/2022~~

~~By (w)~~

~~25/5/2022~~

~~Director (w)~~
~~25/5/22~~

~~ADO (B.W)~~
~~19/5/22~~

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

~~Copy of FT letter in put up for signi please~~

~~ADO (B.W)~~
~~26/5/22~~

~~Director (pfs)~~
~~26/5/22~~

~~me~~