

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**


No. F6/DFS/MS/ WZ/2022/CNG/247

Dated: 03/06/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **CNG Station, Service Centre No. S - 18**, Located at **Pitampura, Sub-Zone, H-4, Delhi** in a building comprised of Ground plus one Upper Floor Owned/Occupied by M/s. **CNG Station, Service Centre No. S - 18**, was issued FSC by this department Vide letter no. F6/DFS/MS/2019/WZ/1127 dated 24/05/2019. The Premises was re-inspected by the officer concerned of this department on 28/04/2022 in the presence of Sh. Gourav Sharma (Manager Fire & Safety) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the said Floor is fit for occupancy class "Hazardous" Group D with effect from 03/06/2022 for a period of three years in accordance with OISD/ 179/ rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. conditions mentions below.

Issued on 03/06/2022 at New Delhi by.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to: - 1. Sh. Ajay Kumar Khatri (DGM-Fire and safety), IGL Bhawan, Plot No.4, Community Centre, Sector - 9, R.K. Puram, New Delhi - 110022.  
2. CNG station, service centre, No.-S-18, Pitampura, Sub Zone, H-4, Delhi.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. **Only Fire protection facilities were checked as per OISD 179 (Para 19). The other safety requirement must be ascertained by licensing authority.**

## INSPECTION REPORT

1. Name & address of the building : CNG Station, Service Center, No-18, Located at Pitampura Sub-Zone, H-4 Delhi
2. Type of Occupancy : Hazardous
3. Type of Case : Renewal
4. Details of previous NOC : F6 DFS MS 2019 WZ 1127 dated 24.05.2019
5. Fire Safety directives letter No : F5(3A)DFS CNG/09/170 dated 16.05.2009
6. Date of inspection : 28/04/2022
7. Name of the Inspecting Officers : Sarabjeet Singh(ADO MN)
8. Name and designation of officers from the building side : Sh. Gourav Sharma ( Station Manager {Fire & Safety} )
9. Year of Construction : 2009 (As per previous insp. report dated 06.05/2019)
10. Applicant's letter No : IGL F&S/2022/15/90/1 dated 11/04/2022

S. No	Minimum Standards on fire prevention and fire safety U/R 33	OISD/179 Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6 mts	30 mtr provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1 mts	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	ISI marked DCP 10 KG & 75 KG, CO <sub>2</sub>	Provided	MR
	• Types		ABC & CO <sub>2</sub> Provided	MR
	• IS marking		Yes	MR

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Hand hold detector	Provided	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	Water mist trolley	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	<b>Exit Signage.</b>	Required	Provided	MR



P119

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	Required	Co2 flooding system provided	MR

**Note: - The availabilities & functioning of fire fighting and detection facilities were checked. The other issues like distance from electric line, Boundary wall, and distance from petrol pump/Gas agency if any, etc must be ascertain by licensing authority.**

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/2019/WZ/1127 dated 24/05/2019 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

Do (w/est)

127/ADOI MN  
02/05/2022

476/DO/WD  
dt. 27/5/2022

02/05/2022  
DFS (WZ)

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADO (MN)

Adm. M-N Sir, F.T is put up for your perusal & signature please.  
By (F0/WZ)  
27/5/2022