

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.**

No. F.6/DFS/MS/CNG/2022/SZ/ 249

Dated: 03/06/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **CNG Station** at Khasra No. 47/16, Village-Paprawat Jhatikra Road, Delhi, comprised of ground floor only, (04 Dispenser with 04 points) owned/occupied by **M/s Indraprastha Gas Limited**. The premises were inspected by the officer concerned of this department on 19/05/2022 in the presence of Sh. Ramniwas Mittal and found that CNG Dispensing Station have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises (**CNG Dispensing Station**) is fit for occupancy class Group "J" Hazardous Building w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on..... 03/06/2022 ..... at New Delhi.

(A.T.H. GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Manager,  
CNG Station at Khasra No. 47/16,  
Village-Paprawat Jhatikra Road, Delhi.
2. The Joint C.P. (Lic.),  
Police Station, Defence Colony, New Delhi

Following fire safety directives must be adhered to

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry

N/2

**INSPECTION REPORT**

1. Name & address of the building : CNG Station at Khasra No. 47/16, Village-Paprawat Jhatikra Road, Delhi.
2. Type of Occupancy : Group "J" Hazardous (CNG Facility)
3. Building comprised of : Ground floor only.
4. Type of Case : New
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : F6/DFS/MS/BP/2019/620 Dated 31/01/2019
7. Date of inspection : 19/05/2022
8. Name of Inspecting Officer : ADO R.K. Yadav
9. Name and designation of officers  
From the building side : Sh. Ramniwas Mittal
10. Year of Construction : 2020-21
11. Applicant's letter No. : IGL/CNG/NOC/02052022 dated 02/05/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NFPA/CCOE/OISD etc. requirements	Provided at site	Remarks MIR/NMR
<b>1.</b>	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<p>12 m NA NA</p>	<p>15 m Provided Directly accessible from road NA</p>	<p>MR NA NA</p>
<b>2.</b>	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	<p>NA NA</p>	<p>NA NA</p>	<p>NA NA</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	<p>NA NA</p>	<p>NA NA</p>	<p>NA NA</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	<p>NA NA</p>	<p>NA NA</p>	<p>NA NA</p>
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
<b>3.</b>	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<p>NA NA NA NA NA</p>	<p>NA NA NA NA NA</p>	<p>NA NA NA NA NA</p>
<b>4.</b>	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	<p>NA NA</p>	<p>NA NA</p>	<p>NA NA</p>
<b>5.</b>	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	<p>10 Nos. Required ISI</p>	<p>Provided 5 Nos. DCP Type (9 kg), 2 Nos. CO2 Type 4.5 kg, 3 Nos. DCP Type (75 kg) trolley mounted Provided</p>	<p>MR MR MR</p>

←

6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	NA	NA	NA
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Gas and flame detectors</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Required	Office at GF	NA
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	Required	At station	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Ground Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Discharge of main Pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Head of Main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Number of main pumps</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Jockey Pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Jockey pump head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Standby Pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Standby Pump Head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Auto Starting/Manual Stopping</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Pump House Access</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Head of the pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Power Supply</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Auto Starting of pump</li> </ul>	NA	NA	NA
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Draw-off connection</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Fire service inlet</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Access to tank</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
15.	<b>No Smoking Signage.</b>	Required	Provided in Hindi & English	MR

16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	<b>Standby power supply</b>	NA	Provided (DG Set)	NA
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	CO <sub>2</sub> flooding system in compressor	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules 2010.

**Note:** Sand buckets are provided in the premises & No smoking boards adequately displayed in English and Hindi.

Advance fire water mist cum foam trolley is provided.  
Two hand held explosive meters are also provided.

*R. K. Yadav*  
24/5/2022

Signature of Inspecting Officer  
Name:- R.K. Yadav  
Designation:- Asstt. Divisional Officer

D.O (South West) *[Signature]* 20/5/22  
*[Signature]*  
Dy. Insp (SP) *[Signature]* 26/5  
F.O. *[Signature]* 29/5/2022  
Director *[Signature]* 27/5/2022

*And JK?*