

416

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No F 6 DFS/MS/School/2022/SZ/ 610

Dated 03 / 06 / 2022

FIRE SAFETY CERTIFICATE

Certified that **Dashmesh Public School**, located at Gurdwara Sri Guru Singh Sabha (Regd.) Gali No -7, Govindpuri New Delhi 110019 comprised of Ground plus Two upper floor owned/occupied by Gurdwara Sri Guru Singh Sabha (Regd.) was issued Fire Safety Certificate by this department vide letter No F6/MS/DFS/School/2017/SZ/1661 Dated 16-11-2017. The said premise was re-inspected by officer concerned of this department on 30/05/2022 in presence of Mrs. Jagot Kaur of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group - B**" with effect from 03/06/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 03/06/2022 at New Delhi by


(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to :-

1. The Principal, Dashmesh Public School, located at Gurdwara Sri Guru Singh Sabha (Regd.) Gali No -7, Govindpuri New Delhi 110019
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/No

INSPECTION REPORT

1	Name & Address of the Building	Dashmesh Public School, located at Gurdwara Sri Guru Singh Sabha (Regd) Gali No -7, Govindpuri New Delhi 110019		
2	Type of Occupancy	Educational, Group- B (School)		
3	Building Comprised of	Ground + Two upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/School/2017/SZ/1661 Dated 16-11-2017		
6	Fire Safety Directives Letter No	DOE Circular 17/01/2005		
7	Date of Inspection	30/05/2022		
8	Name of the Inspecting Officers	Sh Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs Jagot Kaur		
10	Year of construction	1998		
11	Applicant letter No	Gmail of dated 26/04/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	Required	6 mtr	MR
	• Gate width	NA	NA	NA
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	02 Nos	Provided	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.50m/0.75m	1.0m & 1.35m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	02 Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	01 mtr	Provided	MR
3.	Compartmentation.			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire rating of shaft door	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	NA
5.	Fire Extinguishers.			
	• Total numbers	Required	06 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor	01 No	Provided	MR
	• Length of hose-reel hose	30m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR
7.	Automatic fire detection & alarming system.			

M12

• Flow switch panel	-NA-	-NA-	-NA-
• PA system panel	-NA-	-NA-	-NA-
• Battery backup	-NA-	-NA-	-NA-
• Building floor plan	-NA-	-NA-	-NA-

20. Special Fire Protection System for the Protection of special Risk, if any.

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No Fo MS/DFS School/2017/SZ/1661 Dated 16-11-2017, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Accordingly DFA is put up for approval and signature please.

AK
31/05/2022

Signature of the Inspecting Officer
Name Sh Rajesh Kumar
Design ADO (BCP)

DO (SD) - on leave

Dy. Col/Sp h

ADK BTR

As approved, f-y. letter is put up for your signature PI

AK
2/6/2022

Dy Col/Sp h

M.S. cell