

0121

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No F6/DFS/MS/School/2022/NDZ/ 601

Dated: 01/06/2022

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Govt. Girls Sr. Sec. School located at A-Block, Nand Nagri, Delhi-110093, comprised of ground plus one upper floor, owned/occupied by M/s Govt. Girls Sr. Sec. School was issued FSC vide letter No. F6/DFS/MS/School/2019/NDZ/1335 dated 24/06/19. The school buildings were re-inspected by the officer concerned of this department on 25/05/2022 in the presence of Mrs. Rajesh, (Vice Principal) and observed that all the Fire prevention and Fire safety arrangements provided in the premises found in good working conditions. The premises have therefore, deemed complied with Director of Education Circular Letter No. F16/Estate/CC/Fire Safety/2011 /3298 to 3398 dated 01/03/11 and that the building is fit for occupancy class "Educational Building " "Group- B" with effect from 01/06/2022 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/06/2022 at New Delhi by

  
11/6/22

(Dr. S.K Tomar)  
Dy. Chief Fire Officer



To,  
The Vice Principal,  
M/s Govt. Girls Sr. Sec. School  
A-Block, Nand Nagri,  
Delhi-110093.

Copy -  
The Dy. Director of Education  
B-Block, Yamuna Vihar,  
Delhi-110053.


## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/12

1. Name & address of the building : Govt. Girls Sr. Sec. School  
A-Block, Nand Nagri, Delhi-93
2. Building is comprised of : Ground plus one upper floor  
(04 separate blocks & 02 blocks interconnected)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2019/NDZ/1335 dated 24/6/19
6. Fire Safety direction letter No : F16/Estate/CC/FireSafety/2011/3298to3398 dt-01/03/11
7. Date of Inspection : 25/05/2022
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of Officer  
from the building side : Mrs. Rajesh, (Vice Principal)
10. Year of Construction : 1991,2012,2015,2016
11. Applicant's letter No : GGSSS/A-BLOCK/NN/2022/47 Dated- 07/05/2022

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	<b>Access to building</b>			
	• Road width	06 mtr.	06 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	<b>Number, Width, Type and Arrangement of Exits</b>			
	<b>a. Number of Staircases</b>			
	• Upper Floor	07 nos.	07 nos.	MR
	• Basement	N/A	N/A	N/A
	<b>B. Width of Staircases</b>			
	• Upper Floor	1.50 mtr	1.50 mtr to 1.80 mtr	MR
	• Basement	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircases to terrace</b>	02 nos.	02 nos.	MR
	<b>e. Width of Corridor</b>	1.50 mtr.	1.50 mtr.	MR
	<b>f. Door Size</b>	01 mtr.	01 mtr.	MR
03	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	<b>Smoke Management System.</b>			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A



05.	Fire Extinguishers			
	• Total numbers	22 nos	24 nos	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage	N/A	N/A	N/A
16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any.	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule the NOC issued vide letter no. F.6/DFS/MS/School/2019/NDZ/1335 dated 24/6/19 renewal under rule 35 of Delhi Fire Service Rules 2010 is recommended

*Mehmood*  
26/5/22  
Signature of the Inspecting Officer  
Name :- Mehmood  
Designation :- A.D.O (T.P)

DO(ED) *[Signature]*  
26/05/2022

Dy. CFO (NDZ) *[Signature]*  
26/5/22

ADDCP) Sir, A.P.T. Letter is pending in the office

Dy. CFO (NDZ) *[Signature]*  
26/5/22

*[Signature]*  
26/5/22  
ADDCP)

