

C/23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**

**NEW DELHI- 110001**


No.F6/DFS/MS/School/2022/SZ/599

Dated: 31/05/2022

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Sarvodaya Kanya Vidyalaya, Mohan Garden, New Delhi-110059, Comprised of ground plus two upper floors only, owned/occupied by Govt. Sarvodaya Kanya Vidyalaya, was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2019/SZ/1510 dated 23/07/2019. The school building was re-inspected by the officer concerned of this department on 23/05/2022 in the presence of Mrs. Sita Viswerwaram (Vice-Principal) and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....31/05/2022..... at New Delhi.

  
**(Sunil Chawdhary)**  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Principal, Govt. Sarvodaya Kanya Vidyalaya, Mohan Garden, New Delhi-110059.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi-54.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Ns

- |   |  |
|---|--|
| 1. Name & address of the building                             | : Govt. Sarvodaya Kanya Vidyalaya, Mohan Garden, New Delhi-59. |
| 2. Building is comprised of                                   | : Ground plus one upper floor (Five Blocks)                    |
| 3. Type of Occupancy  | : Educational  |
| 4. Type of Case   | : Renewal  |
| 5. Details of Previous FSC letter                             | : F.6/DFS MS/School/2019/SZ/1510 dated 23/07/2019              |
| 6. Fire Safety direction letter No                            | : DOE Circular Dated 1.3. 2011                                 |
| 7. Date of Inspection   | : 23/05/2022   |
| 8. Name of the Inspecting officers                            | : ADO R.K. Yadav   |
| 9. Name and designation of Officer:<br>From the building side | : Mrs. Sita Viswerwaram (Vice-Principal)<br>: 2011             |
| 10. Year of Construction                                      | : 2011   |
| 11. Applicant's letter No                                     | : GSKV/MG/2022/158 Dated- 06/05/2022                           |

S	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building	06 m.	Provided	MR
	• Road width			
	• Gate width	4.5 m	Direct accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	08 Nos.	08 Nos	MR
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	B. Width of Staircases	1.50 & .75 m	1.45, 1.40, 1.56, 1.40, 1.50, 1.48, 1.41, 1.40 m	MR
	• Upper Floor			
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	20 nos	Provided	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	IS I marked	ISI marked	MR

A

6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR



1/11

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC was issued vide letter number F.6/DFS/MS/School/2019/SZ/1510 dated 23/07/2019 renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

*Receipt*  
24/5/2022

Signature of the Inspecting Officer  
Name- R.K. Yadav  
Designation- A.D.O (JKP)

DO (South West)

*Signature*  
25/5/22

Dy CEO (SZ)

*Signature*

M.S. Cell  
Put up FT letter  
2015

ADO (SJKP/MS)

FT letter is put up for signature

Dy CEO (SZ)

*Signature*

M.S. Cell

*Receipt*  
31/5/2022