

120

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F6/DFS/MS/School/2022/NDZ/ 600

Dated 31/05/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Gyandeeep Vidya Bhawan Sr. Sec. School located at C-10 Yamuna Vihar, Delhi-110053, A-Block comprised of ground plus two upper floors & B-Block ground plus one upper floor, owned/occupied by Gyandeeep Vidya Bhawan Sr. Sec. School was issued FSC vide letter No. F6/DFS/MS/School/2019/NDZ/876 dated 22/04/19. The school building was re-inspected by the officer concerned of this department on 11/05/2022 in the presence of Mrs. Seema Gupta, Principal of the school and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the school building fit for occupancy class 'Educational Building' "Group-B" with effect from 31/05/2022 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf

Issued on 31/05/2022 at New Delhi by


31/5/22

(Dr S.K Tomar)
Dy.Chief Fire Officer

To,
The Manager,
M/s Gyandeeep Vidya Bhawan Sr. Sec. School
C-10 Yamuna Vihar,
Delhi-110053

Copy -
The Dy. Director of Education,
B- Block, Yamuna Vihar,
Delhi-110053

-A o/c

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form `J` [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building	Gyandeep Vidya Bhawan Sr Sec School C-10 Yamuna Vihar, Delhi-53
2. Building is comprised of	A-Block- G+2 & B-Block-G+1
3. Type of Occupancy	Educational
4. Type of Case	Renewal
5. Details of Previous NOC letter	F6/DFS/MS/School/2019/NDZ/876 dated 22/04/19
6. Fire Safety direction letter No	NBC Part-IV
7. Date of Inspection	11/05/2022
8. Name of the Inspecting officers	ADO Mehmood
9. Name and designation of Officer from the building side	Mrs. Seema Gupta (Principal)
10. Year of Construction	1991, 2016
11. Applicant's letter No	Email, Dated- 22/04/2022

Sr. No	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	07 mtr.	MR
	• Gate width	4 50 mtr	4 50 mtr	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	01 No. in each Block	A-Block 02 no. & B-Block 02 nos.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	1.50 mtr.	1.40 mtr & 1.50 mtr	MR
	• A-Block	1.50 mtr.	1.35 mtr & 0.75 mtr	MR
	• B-Block	N/A	N/A	N/A
	• Basement			
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 No.	01 No. in each Block	MR
	e. Width of Corridor	1.50 mtr.	1.40 mtr to 1.50 mtr.	MR (Old accepted)
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	10 nos.	10 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

- 1 Name & address of the building : Gyandeeep Vidya Bhawan Sr. Sec. School ,
C-10 Yamuna Vihar, Delhi-53
- 2 Building is comprised of : A-Block- G+2 & B-Block-G+1
- 3 Type of Occupancy : Educational
- 4 Type of Case : Renewal
- 5 Details of Previous NOC letter : F6/DFS/MS/School/2019/NDZ/876 dated 22/04/19
- 6 Fire Safety direction letter No : NBC Part-IV
- 7 Date of Inspection : 11/05/2022
- 8 Name of the Inspecting officers : ADO Mehmood
- 9 Name and designation of Officer
from the building side : Mrs. Seema Gupta (Principal)
- 10 Year of Construction : 1991, 2016
- 11 Applicant's letter No : Email, Dated- 22/04/2022

Sr. No	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	07 mtr.	MR
	• Gate width	4.50 mtr	4.50 mtr	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	01 No. in each Block	A-Block 02 no. & B-Block 02 nos	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	1.50 mtr.	1.40 mtr & 1.50 mtr	MR
	• A-Block	1.50 mtr.	1.35 mtr & 0.75 mtr	MR
	• B-Block	N/A	N/A	N/A
	• Basement			
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 No.	01 No. in each Block	MR
	e. Width of Corridor	1.50 mtr.	1.40 mtr to 1.50 mtr.	MR (Old accepted)
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05	Fire Extinguishers.			
	• Total numbers	10 nos.	10 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector system panel Flow switch panel PA system panel Battery backup Building floor plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any.	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issue vide letter No. F6/DFS/MS/School/2019/NDZ/876 dated 22/04/19 renewal under the rule 35 of Delhi Fire Service Rules 2010 is recommended

Power as contained in the enclosed copy which is only for reference
 and
 Signature of the Inspecting Officer
 Name :- Mehmood
 Designation :- A.D.O (T.P)

~~Dy. C.F.O (NDZ)~~

I - Application was sent to you on 25/04/2022 and inspection report is put up on today. Pl. explain reason for delay.


AD O I T/P. Sir as you aware I was in medical rest the delay is regret Sir,

Y K R / NDZ

Th
25/5/22
ano

1. Route through DO(ED) in future.
2. Pl. read DFA before submission for errors.

AD O (T.P) Sir. It regarding the info with all the file received that DO as only



Th
27/5/22

Th
20/5/22