

C/39

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2022/SZ/608

Dated: 01/06/2022

FIRE SAFETY CERTIFICATE

Certified that the **Pioneer Kamal Convent School (Wing-B)**, 31, 33, 34A, 34 & 35, A-Block, Pioneer Road, Vikas Nagar, New Delhi-110059 comprised of basement, ground floor plus three upper floors, was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2019/SZ/595 dated 22/03/2019 owned/occupied by Pioneer Kamal Convent School. The school building was re-inspected by the officer concerned of this department on 23/05/2022 in the presence of Smt. Savita Wason (Principal) and found that the School building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....01/06/2022..... at New Delhi.


(SUNIL CHAUDHARY)
DY.CHIEF FIRE OFFICER

Copy to:-

1. The Principal,
Pioneer Kamal Convent School (Wing-B), 31, 33, 34A, 34 & 35,
A-Block, Pioneer Road, Vikas Nagar, New Delhi-110059.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall not be used for school activities.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/20

INSPECTION REPORT

| | |
|---|---|
| 1. Name & address of the building | Pioneer Kamal Convent School (Wing-B), 31, 33, 34A, 34 & 35, A-Block, Pioneer Road, Vikas Nagar, New Delhi-110059 |
| 2. Building comprised of | Basement, Ground plus three upper floors |
| 3. Type of Occupancy | Educational |
| 4. Type of Case | Renewal |
| 5. Details of Previous NOC | F 6/DFS/MS/School/2019/SZ/595 dated 22/03/2019 |
| 6. Fire Safety directives letter No | N/A |
| 7. Date of inspection | 23/05/2022 |
| 8. Name of Inspecting Officer | A.D.O. R.K. Yadav |
| 9. Name and designation of officers From the building side | Sh. Pramod Kumar |
| 10. Year of Construction | Before 2015 |
| 11. Applicant's letter No | Outdoor Diary no 1005 dated 04/05/2022 |

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC requirements | Provided at site | Remarks MR/NMR |
|--------|---|---|---|---|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | Accessible 4.5 m N/A | 06 m Directly accessible from road N/A | M/R, as per tehsildar (dwarka) certificate MR N/A |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floors Basements | 02 No.'s 02 No.'s | 02 No.'s 02 No.'s | M/R M/R |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floor Basements | 1.50 m 1.50 m | 1.50 m each 1.50 m each | M/R M/R |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> Fire check door Pressurization | Required N/A | Provided N/A | M/R N/A |
| | d. No. of continuous staircases to terrace | | | |
| | e. Width of Corridor | Required | Provided | M/R |
| | f. Door Size | 1.50 m | 1.85 m | M/R |
| | | 1.20/1.0 m | 1.20 & 1.0 m (Double door) | M/R, students are less than 45 in each class room |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | Required Required | Exhaust fans are provided Natural ventilation provided | M/R M/R |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 10 no's ABC/CO ₂ type ISI marked | Provided Provided Provided | M/R M/R M/R |


| | | | | | |
|-----|---|--|---|--|--|
| 6. | First-Aid Hose Reels | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | One 30 mtrs 5 mm | Provided Provided Provided | M/R M/R M/R |
| 7. | Automatic fire detection and alarming system | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| 8. | MOEFA | | N/A | N/A | N/A |
| 9. | Public Address System | | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | <ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling | Required N/A N/A | Provided N/A N/A | M/R N/A N/A |
| 11. | Internal Hydrants | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | N/A N/A N/A | N/A N/A N/A | N/A N/A N/A |
| 12. | Yard Hydrants | <ul style="list-style-type: none"> Total number of hydrants Hose Box | N/A N/A | N/A N/A | N/A N/A |
| 13. | Pumping Arrangements | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 450 LPM (02 no.'s) 30 mtrs Required Required | N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A Provided Provided Provided Provided | N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A M/R M/R M/R M/R |
| 14. | Captive Water Storage for fire fighting | <ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity | N/A N/A N/A N/A 15000 ltrs Required | N/A N/A N/A N/A Provided Provided | N/A N/A N/A N/A M/R M/R |
| 15. | Exit Signage. | | | | |

| | | No Lift | | |
|-----|--|---------|-----|-----|
| 16. | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | N/A | N/A | N/A |
| | • Fireman's Grounding Switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17. | Standby power supply | N/A | N/A | N/A |
| 18. | Refuge Area. | | | |
| | > Total Area | N/A | N/A | N/A |
| | > Location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | N/A | N/A | N/A |


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F6/DPS/MS/School/2019/SZ/595 dated 22/03/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of Inspecting Officer
 Name - R.K. Yadav
 Designation:- Asstt. Divisional Officer

D.O. (South West)  27/5/22

Dy. CRO (Sp)  F.T.

A.O. (K.P.)  F.T. Letter is put up for signature

Dy. CRO (Sp)  M.S.  31/5/2022