

12
C27

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2022/ School/ 603

Dated: 01/06/2022

FIRE SAFETY CERTIFICATE

Certified that the **S.D. Bankey Bihari Vidya Mandir** located at **3180, Bankey Bihari Mandir Marg, Pahar Ganj, New Delhi** comprises of **Ground + 02 Upper floors, school running at ground only** owned/occupied by S.D. Bankey Bihari Vidya Mandir was earlier granted FSC by this department vide letter No. **F6/DFS/MS/2019/School/64 dated 08/01/2019 (for ground floor only)**. Now, the premises was re-inspected by the officer concerned of this department on 09-05-2022 in the presence of Smt. Alka Sharma and found that the **said school running on ground and first floor**, has complied with the fire prevention and fire safety requirements in accordance with director of education circular dated 01.03.2011 and that the premises is fit for occupancy of class **Group B "Educational Building" Sub-Div. B-I ground and first floor only** with effect from **01/06/2022** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.
Issued on **01/06/2022** at New Delhi by.


(Atul Gang)
DIRECTOR
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT, Delhi.
2. The Principal,
S.D. Bankey Bihari Vidya Mandir 3180, Bankey Bihari Mandir Marg, Pahar Ganj, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. This FSC is valid only for ground & first floor school premises.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building:- S.D. Bankey Bihari Vidya Mandir, 3180, Bankey Bihari Mandir Marg, Pahar Gnaj, New Delhi.
2. Type of occupancy:- Educational Building, Gr. + 02 upper floor
School is running at ground and first floor
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/2019/School/64 dated 08/01/19.
5. Fire safety directives No.- N/A
6. Date of inspection:- 09/05/22
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Smt. Alka Sharma
1961
9. Year of construction:- Nil dated 11/03/2022
10. Applicant's letter No:-

Building is comprised of ground and two upper floor and school is running at ground and first floor and office at second floor.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per dir. of education circular	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Accessible	06 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01	01	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	1.5 & .75 mtr. up to first floor	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	1.5 mtr.	1.5 mtr.	MR
	F. Door size	1.0 mtr.	1.0 mtr	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	08 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 & W CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			

✓

M/19

	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR

✓

22/20

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Further, building is comprised of ground and two upper floors and school is earlier running at ground floor and now running at ground and first floor and complied the fire safety arrangements as per circular of Director of Education dated 01.03.2011. However, as per circular fire extinguishers are the requirements, if the school is running at ground plus one story. Accordingly, If agreed, we may issue the FSC for ground and first floor.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the circular of director of education, if approved, we may issue the FSC as per Delhi Fire Service rules 2010.

Signature of the Inspecting Officer

[Handwritten Signature]

Name :- Ravinder Singh
Designation :- A. D.O. (CC)

DOCD

[Handwritten Signature]
27/5/22

Dy. C.F.O. (CC-2)

[Handwritten Signature]
27/5/22



CFO
[Handwritten Signature]
20/5/2022

[Handwritten Signature]
27/5/22

[Handwritten Signature]